

Lyn Knoll - Sampled 11/18/16

Source types: Drinking fountain= **DF**, Sink= **SK**, Water Bottle Filler= **BF**, Sink Bubbler= **SKB**, Insta Hot Dispenser= **IHD**, Water Dispenser= **WD**, Pot Filler= **PF** (e.g. 114- **SK** -01, 122- **SKB** -04).

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Lyn Knoll	SK	Food Prep Sink/Kitchen	128-SK-1	1.39
Lyn Knoll	DF	Hallway by cafeteria	128-DF-2	<1
Lyn Knoll	SK	Workroom in office	128-SK-3	6.57
Lyn Knoll	SK	Staff Lounge	128-SK-4	<1
Lyn Knoll	SK	Clinic	128-SK-5	<1
Lyn Knoll	SKB	Classroom K1	128-SKB-6	<1
Lyn Knoll	DF	Hallway across from K2	128-DF-7	<1
Lyn Knoll	SK	Classroom K2	128-SK-8	<1
Lyn Knoll	SK	Classroom A1	128-SK-9	<1
Lyn Knoll	SKB	Classroom A2	128-SKB-10	<1
Lyn Knoll	SKB	Classroom A3	128-SKB-11	<1
Lyn Knoll	SKB	Classroom A4	128-SKB-12	<1
Lyn Knoll	SKB	Classroom A5	128-SKB-13	<1
Lyn Knoll	DF	Hallway in B Wing	128-DF-14	<1
Lyn Knoll	SK	Classroom B3	128-SK-15	>20
Lyn Knoll	SK	Classroom B3 resample after replacement	128-SK-15C	<1
Lyn Knoll	SKB	Classroom B4	128-SKB-16	1.41
Lyn Knoll	SKB	Classroom B5	128-SKB-17	<1
Lyn Knoll	SKB	Computer lab	128-SKB-18	<1
Lyn Knoll	SK	Classroom B3	128-SK-19	<1