

Park Lane - Sampled 11/11/2016

Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IDH, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK -01, 122- SKB -04).

Aurora Public Schools	Type	Description	Label	Leac Result ppb = parts per billion
Park Lane	SK	Food Prep Sink/Kitchen	136-SK-1	<1
Park Lane	DF	Hallway by Office	136-DF-2	<1
Park Lane	SK	Clinic	136-SK-3	<1
Park Lane	SK	Staff Lounge	136-SK-4	<1
Park Lane	IDH	Staff Lounge	136-IHD-5	<1
Park Lane	SKB	Classroom 23	136-SKB-6	6.21
Park Lane	SKB	Classroom 24	136-SKB-7	<1
Park Lane	SKB	Classroom 25	136-SKB-8	<1
Park Lane	SK	Classroom 1	136-SK-9	2.06
Park Lane	SKB	Classroom 2	136-SKB-10	<1
Park Lane	SKB	Classroom 9	136-SKB-11	<1
Park Lane	SKB	Classroom 3	136-SKB-12	<1
Park Lane	SKB	Classroom 8	136-SKB-13	<1
Park Lane	SKB	Classroom 4	136-SKB-14	<1
Park Lane	SKB	Classroom 7	136-SKB-15	<1
Park Lane	SKB	Classroom 5	136-SKB-16	1.28
Park Lane	SKB	Classroom 6	136-SKB-17	<1
Park Lane	SKB	Classroom 17	136-SKB-18	<1
Park Lane	SKB	Classroom 18	136-SKB-19	<1
Park Lane	SKB	Classroom 19	136-SKB-20	<1
Park Lane	SKB	Classroom 22	136-SKB-21	<1
Park Lane	SKB	Classroom 20	136-SKB-22	<1
Park Lane	SKB	Classroom 21	136-SKB-23	<1
Park Lane	SKB	Classroom 16	136-SKB-24	<1
Park Lane	SKB	Classroom 15	136-SKB-25	<1
Park Lane	SKB	Classroom 14	136-SKB-26	<1
Park Lane	SKB	Classroom 12	136-SKB-27	Not tested/Water was off will retest when fixed