

Crawford/Kids Clinic - Sampled 11/11/2016

Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IHD, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK -01, 122- SKB -04).

Aurora Public Schools	Type	Description	Label	Lead Result ppb= parts per billion
Crawford	DF	Hallway by office	110-DF-1	<1
Crawford	SKB	Classroom 1	110-SKB-2	<1
Crawford	SKB	Classroom 65	110-SKB-3	<1
Crawford	SKB	Classroom 3	110-SKB-4	<1
Crawford	SKB	Classroom 66	110-SKB-5	<1
Crawford	DF	Hallway by rm 4	110-DF-6	<1
Crawford	SKB	Classroom 6	110-SKB-7	<1
Crawford	SKB	Classroom 11	110-SKB-8	1.58
Crawford	SKB	Classroom 7	110-SKB-9	<1
Crawford	SKB	Classroom 12	110-SKB-10	<1
Crawford	SKB	Classroom 8	110-SKB-11	<1
Crawford	SKB	Classroom 13	110-SKB-12	<1
Crawford	SKB	Classroom 9	110-SKB-13	1.07
Crawford	SKB	Classroom 14	110-SKB-14	<1
Crawford	SKB	Classroom 10	110-SKB-15	4.62
Crawford	SK	Classroom 15	110-SK-16	1.08
Crawford	SKB	Office in Media Center	110-SKB-17	2.82
Crawford	SKB	Classroom 26	110-SKB-18	1.77
Crawford	SKB	Classroom 27	110-SKB-19	2.42
Crawford	SKB	Classroom 28	110-SKB-20	2.88
Crawford	SKB	Classroom 29	110-SKB-21	1.98
Crawford	SKB	Classroom 24	110-SKB-22	4.28
Crawford	SKB	Classroom 30	110-SKB-23	2.18
Crawford	DF	Hallway by rm 31	110-DF-24	1.87
Crawford	SKB	Classroom 32	110-SKB-25	<1
Crawford	SK	Rm 35	110-SK-26	1.54
Crawford	SKB	Classroom 33	110-SKB-27	<1
Crawford	SKB	Classroom 34	110-SKB-28	<1
Crawford	SKB	Kid's Clinic Office	110M-SKB-29	2.27
Crawford	SK	Kid's Clinic Lounge	110M-SK-30	1.35
Crawford	SK	Kid's Clinic Intake room	110M-SK-31	2.20
Crawford	SK	Kid's Clinic consult room	110M-SK-32	1.71
Crawford	SK	Kid's Clinic consult room	110M-SK-33	2.10
Crawford	SK	Kid's Clinic consult room	110M-SK-34	1.53
Crawford	SKB	Kid's Clinic consult room	110M-SK-35	2.49
Crawford	DF	Hallway by room 39	110-DF-36	1.05
Crawford	SKB	Classroom 48	110-SKB-37	1.64
Crawford	SKB	Classroom 47	110-SKB-38	1.20
Crawford	SKB	Classroom 46	110-SKB-39	<1
Crawford	SKB	Classroom 45	110-SKB-40	<1
Crawford	SKB	Classroom 44	110-SKB-41	1.53
Crawford	SKB	Classroom 40	110-SKB-42	1.74

Crawford/Kids Clinic - Sampled 11/11/2016

*Source types: Drinking fountain= **DF**, Sink= **SK**, Water Bottle Filler= **BF**, Sink Bubbler= **SKB**, Insta Hot Dispenser= **IHD**, Water Dispenser= **WD**, Pot Filler= **PF** (e.g. 114- **SK**-01, 122- **SKB** -04).*

Aurora Public Schools	Type	Description	Label	Lead Result ppb= parts per billion
Crawford	SKB	Classroom 41	110-SKB-43	4.00
Crawford	SKB	Classroom 42	110-SKB-44	4.78
Crawford	SKB	Classroom 43	110-SKB-45	3.36
Crawford	DF	Hallway by room 49	110-DF-46	1.52
Crawford	SK	Food Prep Sink/Kitchen	110-SK-47	<1
Crawford	SK	Staff Lounge	110-SK-48	<1
Crawford	SK	Clinic Sink	110-SK-49	<1