

Vassar - Sampled 12/2/2016

*Source types: Drinking fountain= **DF**, Sink= **SK**, Water Bottle Filler= **BF**, Sink Bubbler= **SKB**, Insta Hot Dispenser= **IHD**, Water Dispenser= **WD**, Pot Filler= **PF** (e.g. 114- **SK** -01, 122- **SKB** -04).*

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Vassar	PF	Pot filler/Kitchen	141-PF-1	1.34
Vassar	SK	Food Prep Sink/Kitchen	141-SK-2	<1
Vassar	DF	Cafeteria by kitchen	141-DF-3	<1
Vassar	SK	Workroom by office	141-SK-4	1.99
Vassar	SK	Clinic	141-SK-5	2.21
Vassar	DF	Hallway by staff RR	141-DF-6	4.98
Vassar	DF	DF in gym	141-DF-7	1.42
Vassar	SK	Classroom 24	141-SK-8	1.78
Vassar	SK	Classroom 22	141-SK-9	1.78
Vassar	DF	Hallway by rm 24	141-DF-10	<1
Vassar	SK	Classroom 21	141-SK-11	3.00
Vassar	SK	Classroom 23	141-SK-12	<1
Vassar	SK	Classroom 20	141-SK-13	2.30
Vassar	SK	Classroom 17	141-SK-14	1.42
Vassar	SK	Classroom 18	141-SK-15	1.81
Vassar	SK	Classroom 19	141-SK-16	3.28
Vassar	DF	Hallway by rm 19	141-DF-17	1.15
Vassar	SK	Classroom 12	141-SK-18	1.34
Vassar	SK	Classroom 13	141-SK-19	9.16
Vassar	SK	Classroom 16	141-SK-20	2.47
Vassar	DF	Hallway by rm 13	141-DF-21	<1
Vassar	SK	Classroom 15	141-SK-22	5.43
Vassar	SK	Classroom 14	141-SK-23	7.17
Vassar	SK	Office in Media Center	141-SK-24	2.61
Vassar	SK	Art Room Left SK	141-SK-25	1.15
Vassar	SK	Art Room Right SK	141-SK-26	<1
Vassar	SK	Classroom 3	141-SK-27	1.39
Vassar	SK	Classroom 6	141-SK-28	2.26
Vassar	SK	Classroom 5	141-SK-29	1.10
Vassar	SK	Classroom 4	141-SK-30	<1
Vassar	DF	Hallway by rm 4	141-DF-31	<1
Vassar	SK	Classroom 10	141-SK-32	<1
Vassar	SK	Classroom 7	141-SK-33	<1
Vassar	DF	Hallway by rm 10	141-DF-34	1.56
Vassar	SK	Classroom 8	141-SK-35	<1
Vassar	SK	Classroom 9	141-SK-36	8.00
Vassar	SK	Classroom 2	141-SK-37	<1
Vassar	SK	DF between rm 2/1	141-SK-38	8.63
Vassar	SK	Classroom 1	141-SK-39	<1
Vassar	SK	Staff Lounge	141-SK-40	<1
Vassar	IHD	Staff Lounge	141-IHD-41	<1