ESC3- Sampled 12/16/2016

*Source types: Drinking fountain= **DF,** Sink= **SK,** Water Bottle Filler= **BF,** Sink Bubbler= **SKB,** Insta Hot Dispenser= **IHD,** Water Dispenser= **WD,** Pot Filler= **PF** (e.g. 114- **SK** -01, 122- **SKB** -04).*

Aurora Public Schools	Type	Description	Label	Lead Result ppb= parts per billion
ESC3	SK	Mix prep area	670-SK-01	<1
ESC3	SK	WD for bread mixer	670-WD-02	1.23
ESC3	SK	SK on West wall of bakery	670-SK-03	<1
ESC3	SK	SK on West wall of bakery	670-SK-04	<1
ESC3	SK	Catering kitchen East wall	670-SK-05	1.05
ESC3	SK	Catering kitchen East wall	670-SK-06	<1
ESC3	SK	Catering kitchen food prep	670-SK-07	1.67
ESC3	SK	Bakery break room	670-IHD-08	<1
ESC3	SK	Bakery break room	670-DF-09	<1
ESC3	SK	Bakery break room	670-SK-10	<1
ESC3	SK	Kitchen by A131 (Not tested on 12-16-16, will test at a later date.)	670-SK-11	
ESC3	DF	Hallway by staff RR	670-DF-12	<1
ESC3	SK	Staff lounge	670-SK-13	<1
ESC3	SK	Staff lounge	670-WD-14	<1