

# General ACM Locations for Team C

Revision Date: **11/30/2016**

Elementary Schools	Tunnels			Ceiling Plenum <sup>2</sup>			Ceiling			Walls		Doors		Floors	Boiler Room			Roof			Fixtures
	TSI-Fittings	TSI-Sealant	TSI-Contam.	Surfacing	TSI-Fittings	TSI-Sealant	Surfacing	Tile	Joint Compound	Joint Compound	Transite	Fire Doors	Non-Rated	Floor Tile <sup>1</sup>	TSI-Fitting	TSI-Sealant	Misc.	Flashing	Felt	Misc.	Counter Tops
Arkansas						X								X		X	Gaskets				Cove base
Century	No ACM Present In Building																				
Dalton				Hangar Adhesive		X								X		X					Covebase adhesiv
Dartmouth								X		X		X		X							
Iowa	No ACM Present In Building																				
Jewell														X							
Side Creek	No ACM Present In Building																				
Tollgate								X		paper adhes											
Vassar						TSI & Duct sealant								X		X & Duct sealant					
Yale														X				X			Cove Base
<b>Middle Schools</b>																					
Aurora Hills	No ACM Present In Building																				
Columbia										Exterior				X							unters, cb adhesi
Aurora Frontier K-8	No ACM Present In Building																				
Mrachek						X 1st Fl.						X		X				X			Countertops
Murphy Creek K-8	No ACM Present In Building																				
<b>High Schools</b>																					
Gateway			X			X	X			X, Surfacing in cavities				X			Gasket				Countertops
Rangeview						X								X		X	RTUs?	X			countertops and hood
<b>Other Locations</b>																					
Meadowood CDC	No ACM Present In Building																				

**TSI** = Thermal Systems Insulation

**Sealant** = Fiberglass Sealant

<sup>1</sup> **Floor Tile may also be located beneath existing carpet / May include vinyl stair tread**

<sup>2</sup> **If ceiling plenum contains surfacing, do not disturb or access through lower ceiling.**

<sup>3</sup> **Surfacing contamination between finished floor and wood sub-floor.**