

Radon test result report for:**KENTON  
KENTON**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7886670	ASSIST PRINCIPAL	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.4 ± 0.4	2017-04-24
7886698	AUDIO/VISUAL	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	4.7 ± 0.5*	2017-04-24
<b>*Resampled using Model 1027 Professional Continuous Radon Monitor. EPA Protocol Avg.= 2.3 pCi/L</b>					
7886642	BLANK	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	< 0.3	2017-04-24
7886653	BLANK	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	< 0.3	2017-04-24
7886643	BLANK	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	< 0.3	2017-04-24
7886691	CAFE	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.3 ± 0.4	2017-04-24
7886669	CLINIC	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.5 ± 0.4	2017-04-24
7886679	COMP LAB	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	2.0 ± 0.4	2017-04-24
7886655	CONF RM	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.7 ± 0.4	2017-04-24
7886656	CONF RM DUP	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.6 ± 0.4	2017-04-24
7886675	CR 1	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	2.3 ± 0.5	2017-04-24
7886005	CR 10	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	1.3 ± 0.4	2017-04-24
7886003	CR 11	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	0.9 ± 0.4	2017-04-24
7886001	CR 12	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	1.3 ± 0.4	2017-04-24
7886002	CR 13	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	0.6 ± 0.4	2017-04-24
7886004	CR 14	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	0.8 ± 0.3	2017-04-24
7886006	CR 15	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	0.9 ± 0.4	2017-04-24
7886695	CR 16	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	1.3 ± 0.4	2017-04-24
7886688	CR 17 ART	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.1 ± 0.4	2017-04-24
7886689	CR 18	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.0 ± 0.4	2017-04-24
7886690	CR 19	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.4 ± 0.4	2017-04-24
7886674	CR 2	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.6 ± 0.4	2017-04-24
7886673	CR 27	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.4 ± 0.4	2017-04-24
7886672	CR 27B	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	0.8 ± 0.3	2017-04-24
7886637	CR 28	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.6 ± 0.4	2017-04-24
7886663	CR 29	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.0 ± 0.4	2017-04-24
7886685	CR 3	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	2.0 ± 0.4	2017-04-24
7886686	CR 3 DUP	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	1.8 ± 0.4	2017-04-24
7886658	CR 30	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	0.7 ± 0.3	2017-04-24
7886657	CR 31	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	0.9 ± 0.4	2017-04-24
7886644	CR 32	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.5 ± 0.4	2017-04-24
7886645	CR 33	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	0.8 ± 0.4	2017-04-24
7886684	CR 4	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	2.6 ± 0.4	2017-04-24
7886700	CR 5	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	1.5 ± 0.4	2017-04-24
7886699	CR 6	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	2.4 ± 0.5	2017-04-24
7886696	CR 7	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	1.8 ± 0.4	2017-04-24
7886697	CR 7 DUP	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	2.0 ± 0.4	2017-04-24

Radon test result report for:**KENTON  
KENTON**

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7886694	CR 8	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	1.3 ± 0.4	2017-04-24
7886497	CR 9	2017-04-18 @ 7:00 am	2017-04-20 @ 8:00 am	0.8 ± 0.4	2017-04-24
7886665	GYM E	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.1 ± 0.4	2017-04-24
7886666	GYM OFFICE	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.2 ± 0.4	2017-04-24
7886664	GYM W	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.5 ± 0.4	2017-04-24
7886692	KITCHEN	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.1 ± 0.4	2017-04-24
7886693	KITCHEN OFFICE	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.8 ± 0.4	2017-04-24
7886641	M WRKRM	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	0.6 ± 0.4	2017-04-24
7886652	M WRKRM DUP	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	0.6 ± 0.4	2017-04-24
7886650	M1	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	< 0.3	2017-04-24
7886651	M2	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	< 0.3	2017-04-24
7886640	M3	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	< 0.3	2017-04-24
7886649	M4	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	0.7 ± 0.4	2017-04-24
7886639	M5	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	< 0.3	2017-04-24
7886648	M6	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	< 0.3	2017-04-24
7886646	M7	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	< 0.3	2017-04-24
7886647	M8	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	< 0.3	2017-04-24
7886638	M8 DUP	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	< 0.3	2017-04-24
7886660	MAIL/COPIER	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	2.2 ± 0.5	2017-04-24
7886676	MEDIA E	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	2.2 ± 0.4	2017-04-24
7886677	MEDIA E DUP	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	2.1 ± 0.4	2017-04-24
7886678	MEDIA OFFICE	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	2.4 ± 0.4	2017-04-24
7886687	MEDIA W	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	2.5 ± 0.5	2017-04-24
7886667	OFFICE	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.6 ± 0.4	2017-04-24
7886682	OFFICE BY AP	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.1 ± 0.4	2017-04-24
7886683	OFFICE BY PRINCI	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.1 ± 0.4	2017-04-24
7886668	PARA WRKRM	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	2.6 ± 0.5	2017-04-24
7886654	PRINCIPAL	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.0 ± 0.4	2017-04-24
7886661	RM 22	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.2 ± 0.4	2017-04-24
7886662	RM 23	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	2.0 ± 0.4	2017-04-24
7886634	RM 24	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.5 ± 0.4	2017-04-24
7886635	RM 25	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.2 ± 0.4	2017-04-24
7886636	RM 25 DUP	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.7 ± 0.4	2017-04-24
7886671	RM 26	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.8 ± 0.4	2017-04-24
7886659	STAFF LOUNGE	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	1.3 ± 0.4	2017-04-24
7886680	WRKRM BY MEDIA	2017-04-18 @ 8:00 am	2017-04-20 @ 8:00 am	2.9 ± 0.5	2017-04-24