

Radon test result report for:**PARK LANE
PARK LANE**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7886705	BLANK	2017-04-04 @ 10:00 am	2017-04-06 @ 8:00 am	< 0.3	2017-04-08
7886706	BLANK	2017-04-04 @ 10:00 am	2017-04-06 @ 8:00 am	< 0.3	2017-04-08
7886727	CAFETERIA	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.9 ± 0.3	2017-04-08
7886728	CAFETERIA DUP	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.8 ± 0.3	2017-04-08
7886725	CLINIC	2017-04-04 @ 8:00 am	2017-04-06 @ 7:00 am	1.5 ± 0.3	2017-04-08
7886746	COUSELOR	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	2.1 ± 0.3	2017-04-08
7886735	CR 1	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.2 ± 0.3	2017-04-08
7886707	CR 12	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.2 ± 0.3	2017-04-08
7886708	CR 13	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.1 ± 0.3	2017-04-08
7886709	CR 14	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.2 ± 0.3	2017-04-08
7886711	CR 15	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.1 ± 0.3	2017-04-08
7886712	CR 16	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.4 ± 0.3	2017-04-08
7886713	CR 17	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.4 ± 0.3	2017-04-08
7886714	CR 18	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.4 ± 0.3	2017-04-08
7886736	CR 2	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.5 ± 0.3	2017-04-08
7886733	CR 2 DUB	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.7 ± 0.3	2017-04-08
7886702	CR 20	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.1 ± 0.3	2017-04-08
7886703	CR 21	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.3 ± 0.3	2017-04-08
7886704	CR 22	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.6 ± 0.3	2017-04-08
7886721	CR 23	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.9 ± 0.3	2017-04-08
7886740	CR 24	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.8 ± 0.3	2017-04-08
7886739	CR 25	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.5 ± 0.3	2017-04-08
7886737	CR 3	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.3 ± 0.3	2017-04-08
7886745	CR 4	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.5 ± 0.3	2017-04-08
7886742	CR 6	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.8 ± 0.3	2017-04-08
7886744	CR 7	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.5 ± 0.3	2017-04-08
7886734	CR 8	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.5 ± 0.3	2017-04-08
7886732	CR 9	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.1 ± 0.2	2017-04-08
7886710	CR14 DUP	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.1 ± 0.3	2017-04-08
7886743	CR5	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	2.5 ± 0.3	2017-04-08
7886722	CUSTODIAL	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	2.0 ± 0.3	2017-04-08
7886720	GYM 1	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	4.0 ± 0.4*	2017-04-08
7886719	GYM 2	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	4.0 ± 0.4*	2017-04-08
*Resampled using Model 1027 Professional Continuous Radon Monitor. EPA Protocol Avg.= 2.6 pCi/L					
7886717	GYM OFFICE	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	2.6 ± 0.3	2017-04-08
7886729	KITCHEN	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.4 ± 0.3	2017-04-08
7886730	KITCHEN CLOSET	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.9 ± 0.3	2017-04-08
7886731	LITERACY	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.3 ± 0.3	2017-04-08

April 10, 2017

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**PARK LANE
PARK LANE**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7886741	MEDIA	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.3 ± 0.3	2017-04-08
7886738	MEDIA DUP	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	1.4 ± 0.3	2017-04-08
7886716	OFFICE BY GYM	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	2.1 ± 0.3	2017-04-08
7886724	PRINCIPAL	2017-04-04 @ 8:00 am	2017-04-06 @ 7:00 am	1.5 ± 0.3	2017-04-08
7886715	PSYCH	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	2.8 ± 0.3	2017-04-08
7886726	SECRETARY	2017-04-04 @ 8:00 am	2017-04-06 @ 7:00 am	1.4 ± 0.3	2017-04-08
7886723	STAFF LOUNGE	2017-04-04 @ 8:00 am	2017-04-06 @ 7:00 am	1.6 ± 0.3	2017-04-08
7886718	STAGE	2017-04-04 @ 8:00 am	2017-04-06 @ 8:00 am	3.6 ± 0.3	2017-04-08

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498