

Radon test result report for:**V. CT
VIRGINIA COURT**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7886052	10	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.6 ± 0.6	2017-04-24
7886057	10 DUP	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.1 ± 0.5	2017-04-24
7886059	11	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.1 ± 0.5	2017-04-24
7886030	12	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.5 ± 0.5	2017-04-24
7886060	14	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.6 ± 0.5	2017-04-24
7886061	15	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.3 ± 0.5	2017-04-24
7886058	17 DUP	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.9 ± 0.5	2017-04-24
7886053	18	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.5 ± 0.5	2017-04-24
7886031	19	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.9 ± 0.5	2017-04-24
7886068	2	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.9 ± 0.5	2017-04-24
7886033	20	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.8 ± 0.5	2017-04-24
7886038	21	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.0 ± 0.5	2017-04-24
7886032	22	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.5 ± 0.5	2017-04-24
7886039	23	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	< 0.3	2017-04-24
7886040	24	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	0.8 ± 0.5	2017-04-24
7886034	25	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.3 ± 0.5	2017-04-24
7886041	26	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.6 ± 0.5	2017-04-24
7886042	26 DUP	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.5 ± 0.5	2017-04-24
7886019	27	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.3 ± 0.5	2017-04-24
7886045	3	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.8 ± 0.5	2017-04-24
7886043	30	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.9 ± 0.5	2017-04-24
7886063	31	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.6 ± 0.5	2017-04-24
7886064	32	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.6 ± 0.5	2017-04-24
7886013	38	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.2 ± 0.5	2017-04-24
7886022	39 CUSTODIAL	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	0.9 ± 0.4	2017-04-24
7886046	4	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.0 ± 0.5	2017-04-24
7886021	40C PE OFF	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	0.8 ± 0.5	2017-04-24
7886047	5	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	2.6 ± 0.6	2017-04-24
7886048	6	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.5 ± 0.5	2017-04-24
7886049	7	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.6 ± 0.4	2017-04-24
7886050	8	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.3 ± 0.5	2017-04-24
7886051	9	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	0.8 ± 0.4	2017-04-24
7886037	AP IN MEDIA	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.6 ± 0.5	2017-04-24
7886288	BLANK	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	< 0.3	2017-04-24
7886289	BLANK	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	0.9 ± 0.4	2017-04-24
7886016	BLANK	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	< 0.3	2017-04-24
7886067	C1	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.2 ± 0.5	2017-04-24

Radon test result report for:**V. CT
VIRGINIA COURT**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7886023	CAFE N	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.1 ± 0.4	2017-04-24
7886024	CAFE S	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.0 ± 0.5	2017-04-24
7886012	CLINIC	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.2 ± 0.5	2017-04-24
7886026	CLINIC DUP	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.4 ± 0.4	2017-04-24
7886011	CONF	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	2.9 ± 0.6	2017-04-24
7886044	GYM N	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.1 ± 0.4	2017-04-24
7886020	GYM S	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	0.6 ± 0.5	2017-04-24
7886014	KITCHEN	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.7 ± 0.5	2017-04-24
7886035	KITCHEN OFF(?)	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.0 ± 0.4	2017-04-24
7886025	LIASON	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.1 ± 0.5	2017-04-24
7886008	LOUNGE	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	2.2 ± 0.6	2017-04-24
7886018	M33 (31 ON FP)??	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.1 ± 0.5	2017-04-24
7886007	M33 DUP (31ONFP)	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	0.8 ± 0.5	2017-04-24
7886036	M34 (32 ON FP)??	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	0.8 ± 0.5	2017-04-24
7886029	M35	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.0 ± 0.5	2017-04-24
7886028	M36	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	0.9 ± 0.5	2017-04-24
7886027	M37	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	0.7 ± 0.4	2017-04-24
7886056	M38	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	0.9 ± 0.4	2017-04-24
7886065	MEDIA N	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	0.8 ± 0.5	2017-04-24
7886055	MEDIA OFF	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.7 ± 0.4	2017-04-24
7886066	MEDIA S	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.8 ± 0.5	2017-04-24
7886017	NOID	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	0.7 ± 0.5	2017-04-24
7886009	PRINCIPAL	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	3.1 ± 0.6	2017-04-24
7886010	SECRETARY	2017-04-17 @ 8:00 am	2017-04-19 @ 8:00 am	1.3 ± 0.5	2017-04-24
7886054	SPEECH	2017-04-17 @ 7:00 am	2017-04-19 @ 8:00 am	1.5 ± 0.5	2017-04-24