

Central HS - Sampled 3/17/17

Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IHD, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK -01, 122- SKB -04).

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Aurora Central	SK	Food Prep Sink/Kitchen	370-SK-1	<1
Aurora Central	PF	Pot Filler/Kitchen		Not used so not tested
Aurora Central	SK	Food Prep Sink/Kitchen	370-SK-3	<1
Aurora Central	SK	Staff lounge	370-SK-4	<1
Aurora Central	SK	Staff lounge	370-SK-5	<1
Aurora Central	DF	Hallway outside staff lounge	370-DF-6	<1
Aurora Central	DF	Hallway by weight rm	370-DF-7	<1
Aurora Central	SK	Office between 722/723	370-SK-8	<1
Aurora Central	SK	Room 736	370-SK-9	<1
Aurora Central	DF	Hallway by west gym	370-DF-10L	<1
Aurora Central	DF	Hallway by west gym	370-DF-11M	<1
Aurora Central	DF	Hallway by west gym	370-DF-12R	<1
Aurora Central	SK	Consession stand right SK	370-SK-13	>20
Aurora Central	SK	Consession stand right SK, resample after replacement	370-SK-13B	5.48
Aurora Central	DF	Pool area by boys room	370-DF-14	1.47
Aurora Central	DF	Pool area by girls room	370-DF-15	4.27
Aurora Central	DF	ROTC Bldg by clinic door	370-DF-16	<1
Aurora Central	BF	ROTC Bldg by clinic door	370-BF-17	<1
Aurora Central	SK	SK in health clinic	370-SK-18	<1
Aurora Central	DF	Hallway between clinic/ROTC	370-DF-19	<1
Aurora Central	SK	Office on ROTC side	370-SK-20	<1
Aurora Central	SK	Art office 409	370-SK-21	<1
Aurora Central	DF	Hallway by 412	370-DF-22	<1
Aurora Central	SK	Classroom 412	370-SK-23	<1
Aurora Central	SK	Classroom 411 - has filter	370-SK-24	<1
Aurora Central	SK	Classroom 381	370-SK-25	2.35
Aurora Central	SK	Rm 378 in room 382	370-SK-26	2.73
Aurora Central	DF	Hallway across from 393	370-DF-27R	3.79
Aurora Central	DF	Hallway across from 393	370-DF-28M	3.77
Aurora Central	DF	Hallway across from 393	370-DF-29L	3.70
Aurora Central	SK	Office 394	370-SK-30	7.98
Aurora Central	SK	Classroom 366	370-SK-31	1.87
Aurora Central	SK	Office 305	370-SK-32	1.72
Aurora Central	SK	Rm 348 in counseling services	370-SK-33	<1
Aurora Central	SK	Rm 354 in life skills	370-SK-34	2.37
Aurora Central	SK	Rm 356 in life skills right SK	370-SK-35	<1
Aurora Central	SK	Rm 356 in life skills left SK	370-SK-36	<1
Aurora Central	SK	Classroom 324	370-SK-37	<1
Aurora Central	SK	Classroom 314	370-SK-38	>20
Aurora Central	SK	Classroom 314 resample after replacement and flush	370-SK-38C	5.82

Central HS - Sampled 3/17/17

*Source types: Drinking fountain= **DF**, Sink= **SK**, Water Bottle Filler= **BF**, Sink Bubbler= **SKB**, Insta Hot Dispenser= **IHD**, Water Dispenser= **WD**, Pot Filler= **PF** (e.g. 114- **SK** -01, 122- **SKB** -04).*

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Aurora Central	DF	Hallway by theater	370-DF-39	<1
Aurora Central	DF	Hallway by stage door	370-DF-40	<1
Aurora Central	DF	Classroom 203/Drama	370-DF-41	<1
Aurora Central	SK	Office 200	370-SK-42	<1
Aurora Central	DF	Hallway by 208	370-DF-43	<1
Aurora Central	SK	Classroom 202/Band right SK	370-SK-44	<1
Aurora Central	SK	Classroom 202/Band left SK	370-SK-45	<1
Aurora Central	DF	Classroom 202	370-DF-46	<1
Aurora Central	DF	Classroom 201	370-DF-47	<1
Aurora Central	SK	Office in admin area 111	370-SK-48	<1
Aurora Central	SK	Conf rm 166 admin	370-SK-49	2.28
Aurora Central	SK	Clinic	370-SK-50	<1
Aurora Central	DF	Hallway by clinic	370-DF-51	<1
Aurora Central	SK	Rm 114 in media center	370-SK-52	<1
Aurora Central	SK	Office 152 in media center	370-SK-53	5.20
Aurora Central	SK	Wrkrm in media center 156	370-SK-54	1.53
Aurora Central	SK	Office 129 in career ctr area	370-SK-55	<1
Aurora Central	DF	Hallway by office 618	370-DF-56L	<1
Aurora Central	DF	Hallway by office 618	370-DF-57M	<1
Aurora Central	DF	Hallway by office 618	370-DF-58R	1.07
Aurora Central	DF	Hallway by office 611	370-DF-59	<1
Aurora Central	SK	Office 611	370-SK-60	<1
Aurora Central	SK	Concession left SK	370-SK-61	7.15
Aurora Central	SK	Hallway by rm 314	370-DF-62	2.25