

## Clyde Miller - Sampled 12/16/16

*Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IHD, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK -01, 122- SKB -04).*

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Clyde Miller P-8	SK	Food Prep Sink/Kitchen	209-SK-1	1.00
Clyde Miller P-8	PF	Pot filler/Kitchen	209-PF-2	8.60
Clyde Miller P-8	DF	Cafeteria by kitchen	209-DF-3	1.58
Clyde Miller P-8	SK	Clinic	209-SK-4	<1
Clyde Miller P-8	DF	Hallway by staff RR	209-DF-5	6.73
Clyde Miller P-8	DF	DF in gym	209-DF-6	1.03
Clyde Miller P-8	SKB	Classroom P	209-SKB-7	2.03
Clyde Miller P-8	SKB	Classroom U	209-SKB-8	1.58
Clyde Miller P-8	SKB	Classroom V	209-SKB-9	1.38
Clyde Miller P-8	SKB	Classroom Q	209-SKB-10	1.01
Clyde Miller P-8	SKB	Classroom R	209-SKB-11	3.35
Clyde Miller P-8	SKB	Classroom W	209-SKB-12	2.11
Clyde Miller P-8	SKB	Classroom X	209-SKB-13	2.27
Clyde Miller P-8	SKB	Classroom Y	209-SKB-14	1.55
Clyde Miller P-8	SKB	Classroom Z	209-SKB-15	1.87
Clyde Miller P-8	SKB	Classroom T	209-SKB-16	2.05
Clyde Miller P-8	SKB	Office in Media Center	209-SKB-17	15.5
Clyde Miller P-8	SKB	Office in Media Center resample after replacement and flush	209-SK-17D	11.00
Clyde Miller P-8	SKB	Classroom N	209-SKB-18	4.16
Clyde Miller P-8	SKB	Classroom J	209-SKB-19	2.64
Clyde Miller P-8	SKB	Classroom I	209-SKB-20	2.94
Clyde Miller P-8	SKB	Classroom D	209-SKB-21	<1
Clyde Miller P-8	SKB	Classroom C	209-SKB-22	<1
Clyde Miller P-8	SKB	Classroom B	209-SKB-23	<1
Clyde Miller P-8	SKB	Classroom A	209-SKB-24	<1
Clyde Miller P-8	SKB	Classroom H	209-SKB-25	2.01
Clyde Miller P-8	SKB	Classroom G	209-SKB-26	2.72
Clyde Miller P-8	SK	Classroom K Left SK	209-SK-27	5.71
Clyde Miller P-8	SK	Classroom K Right SK	209-SK-28	8.64
Clyde Miller P-8	SKB	Classroom F	209-SKB-29	2.82
Clyde Miller P-8	SK	Classroom E	209-SK-30	2.20
Clyde Miller P-8	SK	Staff lounge	209-SK-31	2.27
Clyde Miller P-8	IHD	Staff lounge	209-IHD-32	<1