

Dalton - Sampled 12/2/16

*Source types: Drinking fountain= **DF**, Sink= **SK**, Water Bottle Filler= **BF**, Sink Bubbler= **SKB**, Insta Hot Dispenser= **IHD**, Water Dispenser= **WD**, Pot Filler= **PF** (e.g. 114- **SK**-01, 122- **SKB** -04).*

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Dalton	PF	Pot filler/Kitchen	111-PF-1	<1
Dalton	SK	Food Prep Sink/Kitchen	111-SK-2	<1
Dalton	DF	Cafeteria by kitchen	111-DF-3	<1
Dalton	SK	Workroom by office w/filter	111-SK-4	2.56
Dalton	SK	Clinic	111-SK-5	1.47
Dalton	DF	Hallway by staff RR	111-DF-6	3.36
Dalton	DF	DF in gym	111-DF-7	1.41
Dalton	SK	Classroom 51	111-SK-8	2.47
Dalton	SK	Classroom 54	111-SK-9	1.20
Dalton	DF	Hallway by room 51	111-DF-10	<1
Dalton	SK	Classroom 53	111-SK-11	1.11
Dalton	SK	Classroom 52	111-SK-12	2.99
Dalton	SK	Classroom 44	111-SK-13	2.15
Dalton	SK	Classroom 41	111-SK-14	6.88
Dalton	SK	Classroom 42	111-SK-15	4.11
Dalton	SK	Classroom 43	111-SK-16	2.34
Dalton	DF	Hallway by room 43	111-DF-17	2.39
Dalton	SK	Classroom 36	111-SK-18	396
Dalton	SK	Classroom 36 resample after replacement and flush	111-SK-18C	10.6
Dalton	SK	Classroom 35	111-SK-19	5.47
Dalton	SK	Classroom 31	111-SK-20	5.38
Dalton	SK	Classroom 34	111-SK-21	4.53
Dalton	DF	Hallway by room 31	111-DF-22	1.28
Dalton	SK	Classroom 33	111-SK-23	2.52
Dalton	SK	Classroom 32	111-SK-24	3.03
Dalton	SK	Office in Media Center	111-SK-25	17.4
Dalton	SK	Office in Media Center, resample after replacement	111-SK-25D	9.14
Dalton	SK	Art Room Left SK	111-SK-26	2.18
Dalton	SK	Art Room Right SK	111-SK-27	2.44
Dalton	SK	Classroom 11	111-SK-28	1.16
Dalton	SK	Classroom 14	111-SK-29	<1
Dalton	DF	Hallway by room 11	111-DF-30	<1
Dalton	SK	Classroom 12	111-SK-31	<1
Dalton	SK	Classroom 13	111-SK-32	1.09
Dalton	SK	Classroom 26	111-SK-33	8.51
Dalton	SK	Classroom 24	111-SK-34	2.53
Dalton	SK	Classroom 21	111-SK-35	14.5
Dalton	SK	Classroom 21, resample after replacement and flush	111-SK-345E	6.2
Dalton	DF	Hallway by room 23	111-DF-36	<1

Dalton - Sampled 12/2/16

*Source types: Drinking fountain= **DF**, Sink= **SK**, Water Bottle Filler= **BF**, Sink Bubbler= **SKB**, Insta Hot Dispenser= **IHD**, Water Dispenser= **WD**, Pot Filler= **PF** (e.g. 114- **SK** -01, 122- **SKB** -04).*

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Dalton	SK	Classroom 22	111-SK-37	6.44
Dalton	SK	Classroom 23	111-SK-38	7.09
Dalton	SK	Classroom K2	111-SK-39	1.87
Dalton	DF	Classroom K1 by RR	111-DF-40	3.21
Dalton	SK	Classroom K1 w/filter	111-SK-41	2.30
Dalton	SK	Staff lounge	111-SK-42	1.76
Dalton	IHD	Staff lounge	111-IHD-43	<1