

ESC2 - Sampled 3/10/17

Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IHD, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK -01, 122- SKB -04).

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
ESC2	DF	Main ent waiting area	640-DF-1	<1
ESC2	BF	Main ent waiting area	640-BF-2	<1
ESC2	SK	Conf rm 102	640-SK-3	<1
ESC2	SK	Staff lounge 1st floor	640-SK-4	<1
ESC2	IHD	Staff lounge 1st floor	640-IHD-5	<1
ESC2	SK	Sunset Peak rm 145	640-SK-6	1.85
ESC2	SK	Meeting rm 223	640-SK-7	1.09
ESC2	DF	Hallway by 224A	640-DF-8	1.38
ESC2	IHD	Staff lounge 2nd floor	640-IHD-9	<1
ESC2	SK	Staff lounge 2nd floor	640-SK-10	<1