

ESC4 - Sampled 3/17/17

*Source types: Drinking fountain= **DF**, Sink= **SK**, Water Bottle Filler= **BF**, Sink Bubbler= **SKB**, Insta Hot Dispenser= **IHD**, Water Dispenser= **WD**, Pot Filler= **PF** (e.g. 114- **SK** -01, 122- **SKB** -04).*

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
ESC4	DF	Hallway by N stairs 2nd flr	600-DF-1	1.86
ESC4	BF	Hallway by N stairs 2nd flr	600-BF-2	1.72
ESC4	SK	RM 115	600-SK-3	2.74
ESC4	SK	Staff lounge	600-SK-4	<1
ESC4	SK	Conf rm A 111	600-SK-5	3.67
ESC4	DF	Hallway by office 110	600-DF-6	<1
ESC4	BF	Hallway by office 110	600-BF-7	<1
ESC4	SK	Office 109A	600-SK-8	1.09
ESC4	DF	Hallway by Conf rm C	600-DF-9	3.48
ESC4	WD	Conf rm C	600-WD-10	<1
ESC4	DF	Central Registration	600-DF-11L	<1
ESC4	DF	Central Registration	600-DF-12R	<1
ESC4	SK	Staff lounge in CR	600-SK-13	<1