

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 1017, 1159
NRSB Device Code 10302

Laboratory Report for:

Property Tested: Project # Early Beginnings

Aurora Public Schools Care of Environmental
1369 Arport Boulevard
Aurora CO 80011

Early Beginnings
812 Jamaica Street
Aurora CO 80010

Log Number	Device Number	Test Exposure Duration:	Area Tested	Result (pCi/L)
1924462	541020	04/19/2016 10:00 am 04/21/2016 2:15 pm	102	0.7
1924463	541021	04/19/2016 10:00 am 04/21/2016 2:15 pm	103	0.6
1924464	541022	04/19/2016 10:00 am 04/21/2016 2:15 pm	104	0.4
1924465	541023	04/19/2016 10:00 am 04/21/2016 2:15 pm	108 Clinic	0.6
1924466	546241	04/19/2016 10:00 am 04/21/2016 2:15 pm	105	0.7
1924467	546242	04/19/2016 10:00 am 04/21/2016 2:15 pm	117	0.8
1924468	546244	04/19/2016 10:00 am 04/21/2016 2:15 pm	118	0.9
1924469	546245	04/19/2016 10:00 am 04/21/2016 2:15 pm	114	1.2
1924470	546246	04/19/2016 10:00 am 04/21/2016 2:15 pm	114 Duplicate	1.3
1924471	546247	04/19/2016 10:00 am 04/21/2016 2:15 pm	124	0.6

Comment: A copy of this report was emailed to bawalker@aps.k12.co.us.

Distributed by: National Safety Products

Date Received: 04/25/2016 Date Logged: 04/25/2016 Date Analyzed: 04/25/2016 Date Reported: 04/25/2016

Report Reviewed By: M. Gray

Report Approved By: Carolyn D. Koke

Disclaimer:

Carolyn D. Koke, President, AccuStar Labs

The uncertainty of this radon measurement is +/- 10%. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 1017, 1159
NRSB Device Code 10302

Laboratory Report for:

Property Tested: Project # Early Beginnings

Aurora Public Schools Care of Environmental
1369 Arport Boulevard
Aurora CO 80011

Early Beginnings
812 Jamaica Street
Aurora CO 80010

Log Number	Device Number	Test Exposure Duration:	Area Tested	Result (pCi/L)
1924472	546249	04/19/2016 10:00 am 04/21/2016 2:15 pm	130	0.7
1924473	546251	04/19/2016 10:00 am 04/21/2016 2:15 pm	134	1.1
1924474	546252	04/19/2016 10:00 am 04/21/2016 2:15 pm	136	0.7
1924475	546253	04/19/2016 10:00 am 04/21/2016 2:15 pm	139	0.7
1924476	546254	04/19/2016 10:00 am 04/21/2016 2:15 pm	140	0.6
1924477	546255	04/19/2016 10:00 am 04/21/2016 2:15 pm	142	0.9
1924478	546260	04/19/2016 10:00 am 04/21/2016 2:15 pm	143	0.6
1924479	546261	04/19/2016 10:00 am 04/21/2016 2:15 pm	143 Duplicate	0.8
1924480	546262	04/19/2016 10:00 am 04/21/2016 2:15 pm	Custodial	0.9
1924481	546263	04/19/2016 10:00 am 04/21/2016 2:15 pm	Field Blank	<0.4

Comment: A copy of this report was emailed to bawalker@aps.k12.co.us.

Distributed by: National Safety Products

Date Received: 04/25/2016 Date Logged: 04/25/2016 Date Analyzed: 04/25/2016 Date Reported: 04/25/2016

Report Reviewed By: M. Gray

Report Approved By: Carolyn D. Koke

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.