



RDS

Environmental

SUMMARY OF RADON INSPECTION

Site Address: **Aurora Frontier**
3200 S Jericho Way
Aurora, CO 80013

| Detector# | Location Room | Placement | Retrieval | Result pCi/L |
|-----------|-----------------|------------------|------------------|-----------------|
| 4138530 | Rec Dean | 10/30/07 8:00 am | 11/1/07 12:25 pm | 4.7 (Elevated) |
| 4138523 | Ast Princ | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138529 | Prin | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138524 | Secty | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138585 | Media N | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138586 | Media | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138589 | Media Office | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138588 | X41 Comp Lab | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138587 | C42 art | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138590 | C43 Music | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138577 | Commons N | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138581 | Copmmons S | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138583 | Kitchen S | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138584 | Kitchen N | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138576 | Gym S | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138579 | Gym N | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138580 | G14 Locker Room | 10/30/07 8:00 am | 11/1/07 12:25 pm | 0.5 |
| 4138578 | G15 Locker Room | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138591 | Town Sq | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138592 | C45 | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138566 | C46 | 10/30/07 8:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138548 | C44 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138559 | E31 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138560 | C38 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138552 | C37 | 10/30/07 9:00 am | 11/1/07 12:25 pm | 0.6 |
| 4138551 | C36 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138550 | C35 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138555 | C34 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138553 | C33 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138554 | C32 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138558 | C31 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138556 | D31 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138549 | S31 | 10/30/07 9:00 am | 11/1/07 12:25 pm | 0.5 |
| 4138557 | C29 | 10/30/07 9:00 am | 11/1/07 12:25 pm | 0.7 |
| 4138562 | E21 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |

| | | | | |
|---------|-----------------|------------------|------------------|----------------|
| 4138570 | C21 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138573 | C22 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138563 | C23 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138569 | C24 | 10/30/07 9:00 am | 11/1/07 12:25 pm | Missing |
| 4138565 | C25 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138568 | C26 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138571 | C26 dup | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 duplicate |
| 4138564 | C27 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138572 | C28 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138567 | D21 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138561 | N12 Cust Office | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138574 | S21 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138575 | C45 | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138582 | Gym Office | 10/30/07 9:00 am | 11/1/07 12:25 pm | <0.3 |
| 4138687 | Blank | | 11/1/07 12:25 pm | <0.3 |
| 4138547 | C18 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138535 | C17 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138546 | C16 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138537 | C15 | 10/30/07 8:00 am | 11/1/07 12:25 | 0.5 |
| 4138538 | C14 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138536 | C13 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138543 | C12 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138539 | C11 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138542 | E11 Wkrm | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138541 | S11 Resource | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138540 | D11 Sm Group | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138544 | K11 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138545 | K12 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138534 | Office A21 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138532 | Office A22 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138533 | Lounge A23 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138531 | Conf | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138528 | Saff Wkrm | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138525 | Wkrm Rec Rm | 10/30/07 8:00 am | 11/1/07 12:25 | 0.6 |
| 4138526 | Clinic A12 | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 |
| 4138527 | Clinic dup | 10/30/07 8:00 am | 11/1/07 12:25 | <0.3 duplicate |

RECOMMENDATIONS

Long term testing is recommended in all rooms with elevated levels. All other rooms indicated radon levels below the EPA action guideline of 4.0 pCi/l. Please call us should you have any questions.

Sincerely,


Tammy Linton

