

Gateway - Sampled 4/7/17

*Source types: Drinking fountain= **DF**, Sink= **SK**, Water Bottle Filler= **BF**, Sink Bubbler= **SKB**, Insta Hot Dispenser= **IHD**, Water Dispenser= **WD**, Pot Filler= **PF** (e.g. 114- **SK** -01, 122- **SKB** -04).*

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Gateway HS	SK	Hand SK1 in Kitchen	372-SK-1	<1
Gateway HS	SK	Food Prep Sink/Kitchen	372-SK-2	2.58
Gateway HS	SK	Food Prep Sink/Kitchen	372-SK-3	1.56
Gateway HS	SK	Hand SK2 in Kitchen	372-SK-4	3.22
Gateway HS	SK	SK in snack bar	372-SK-5	1.86
Gateway HS	SK	Upper commons	372-SK-6	1.05
Gateway HS	DF	Hallway by upper commons	372-DF-7R	<1
Gateway HS	DF	Hallway by upper commons	372-DF-8L	<1
Gateway HS	DF	Auditorium lobby by RRs	372-DF-9L	<1
Gateway HS	DF	Auditorium lobby by RRs	372-DF-10R	<1
Gateway HS	DF	Boys lckr rm 928	372-DF-11	3.98
Gateway HS	SK	Trainer room	372-SK-12	1.77
Gateway HS	DF	Weight rm 933	372-DF-13	<1
Gateway HS	DF	Girls lckr rm 938	372-DF-14	12.8
Gateway HS	DF	Hallway by girls lckr 938	372-DF-15	<1
Gateway HS	DF	Pool by girls lckr rm 904	372-DF-16	6.86
Gateway HS	WD	Womens coaches office	372-WD-17	<1
Gateway HS	DF	Main gym 901	372-DF-18	1.53
Gateway HS	WD	Mens coaches office	372-WD-19	<1
Gateway HS	SK	Main office wrkrm	372-SK-20	<1
Gateway HS	WD	Main office wrkrm	372-WD-21	<1
Gateway HS	WD	Counseling wrkrm	372-WD-22	<1
Gateway HS	SK	Counseling wrkrm	372-SK-23	<1
Gateway HS	DF	Hallway by rm 106	372-DF-24	1.43
Gateway HS	DF	Hallway by Eng. office 300	372-DF-25	<1
Gateway HS	WD	Soc St office 212	372-WD-26	<1
Gateway HS	SK	Soc St office 212	372-SK-27	<1
Gateway HS	SK	English office/copier rm	372-SK-28	<1
Gateway HS	WD	English office/copier rm	372-WD-29	<1
Gateway HS	SK	Office 330	372-SK-30	<1
Gateway HS	SK	Classroom 333	372-SK-31	<1
Gateway HS	SK	Classroom 320	372-SK-32	<1
Gateway HS	SK	Media center behind desk	372-SK-33	4.74
Gateway HS	SK	Media center behind desk	372-SK-34	<1
Gateway HS	SK	Math office	372-SK-35	<1
Gateway HS	DF	Hallway by rm 502	372-DF-36	1.97
Gateway HS	DF	Bldg outside 502	372-DF-37	<1
Gateway HS	SK	Bldg outside 502	372-SK-38	1.19
Gateway HS	SK	Gen ed office/life skills	372-SK-39	1.11
Gateway HS	WD	Gen ed office/life skills	372-WD-40	<1
Gateway HS	DF	Hallway by Gen ed office	372-DF-41	3.17
Gateway HS	SK	Rm 509 life skills	372-SK-42	<1

Gateway - Sampled 4/7/17

*Source types: Drinking fountain= **DF**, Sink= **SK**, Water Bottle Filler= **BF**, Sink Bubbler= **SKB**, Insta Hot Dispenser= **IHD**, Water Dispenser= **WD**, Pot Filler= **PF** (e.g. 114- **SK** -01, 122- **SKB** -04).*

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Gateway HS	SK	Clinic	372-SK-43	1.07
Gateway HS	WD	Clinic	372-WD-44	<1
Gateway HS	SK	Art office	372-SK-45	1.28
Gateway HS	SK	Classroom 602 SK1	372-SK-46	<1
Gateway HS	SK	Classroom 602 SK2	372-SK-47	9.19
Gateway HS	SK	Classroom 602 SK3	372-SK-48	2.62
Gateway HS	SK	Classroom 602 SK4	372-SK-49	1.20
Gateway HS	SK	Classroom 602 SK5	372-SK-50	1.21
Gateway HS	SK	Classroom 602 SK6	372-SK-51	<1
Gateway HS	SK	Classroom 602 SK7	372-SK-52	<1
Gateway HS	DF	Hallway by rm 605	372-DF-53	<1
Gateway HS	SK	Classroom 603	372-SK-54	2.14
Gateway HS	DF	Hallway by RRs	372-DF-55	<1
Gateway HS	DF	Math office	372-DF-56	<1