

## Hinkley - Sampled 4/7/17

*Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IHD, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK -01, 122- SKB -04).*

<b>Aurora Public Schools</b>	<b>Type</b>	<b>Description</b>	<b>Label</b>	<b>Lead Result ppb = parts per billion</b>
Hinkley HS	PF	Pot Filler/Kitchen	374-PF-1	<1
Hinkley HS	SK	Food Prep Sink/Kitchen	374-SK-2	1.59
Hinkley HS	SK	Food Prep Sink/Kitchen	374-SK-3	<1
Hinkley HS	SK	Classroom 2350	374-SK-4	<1
Hinkley HS	DF	Hallway by rm 2301	374-DF-5L	<1
Hinkley HS	DF	Hallway by rm 2301	374-DF-6R	<1
Hinkley HS	SK	Classroom 2306 right SK	374-SK-7	<1
Hinkley HS	SK	Classroom 2306 left SK	374-SK-8	<1
Hinkley HS	SK	Classroom 2308 right SK	374-SK-9	<1
Hinkley HS	SK	Classroom 2308 left SK	374-SK-10	<1
Hinkley HS	DF	DF in East commons	374-DF-11	<1
Hinkley HS	DF	Hallway by stairs to gym lobby	374-DF-12R	1.25
Hinkley HS	DF	Hallway by stairs to gym lobby Not working so not tested		
Hinkley HS	SK	Wrkrm 2508 in media center	374-SK-14	<1
Hinkley HS	DF	Hallway by elevator 2nd fl	374-DF-15L	<1
Hinkley HS	DF	Hallway by elevator 2nd fl	374-DF-16R	<1
Hinkley HS	SK	Staff lounge/2nd fl	374-SK-17	<1
Hinkley HS	DF	Hallway by staff RR E side2ndfl	374-DF-18R	1.51
Hinkley HS	DF	Hallway by staff RR E side2ndfl	374-DF-19L	<1
Hinkley HS	DF	Hallway by rm 2210	374-DF-20L	1.03
Hinkley HS	DF	Hallway by rm 2210	374-DF-21R	1.00
Hinkley HS	DF	Hallway by rm 2209	374-DF-22L	1.07
Hinkley HS	DF	Hallway by rm 2209	374-DF-23R	1.09
Hinkley HS	DF	Hallway by staff RR W side2ndfl	374-DF-24R	<1
Hinkley HS	DF	Hallway by staff RR W side2ndfl	374-DF-25L	<1
Hinkley HS	DF	Hallway by west commons	374-DF-26L	<1
Hinkley HS	DF	Hallway by west commons	374-DF-27R	<1
Hinkley HS	SK	Wrkrm 1439	374-SK-28	1.08
Hinkley HS	DF	Hallway by 1409/Drama	374-DF-29L	1.94
Hinkley HS	DF	Hallway by 1409/Drama	374-DF-30R	1.41
Hinkley HS	DF	Hallway by band rm	374-DF-31L	4.51
Hinkley HS	DF	Hallway by band rm	374-DF-32R	5.07
Hinkley HS	DF	Classroom 1414/Vocal	374-DF-33	1.25
Hinkley HS	DF	Hallway by pool entrance	374-DF-34	1.65
Hinkley HS	DF	DF in pool area by entrance	374-DF-35	<1
Hinkley HS	DF	Hallway by main lobby stairs	374-DF-36L	<1
Hinkley HS	DF	Hallway by main lobby stairs	374-DF-37R	<1
Hinkley HS	SK	Clinic	374-SK-38	<1
Hinkley HS	SK	Back office lounge	374-SK-39	<1
Hinkley HS	SK	Staff lounge/1st fl	374-SK-40	<1
Hinkley HS	DF	Hallway by staff RR W side 1stfl	374-DF-41L	<1

## Hinkley - Sampled 4/7/17

*Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IHD, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK -01, 122- SKB -04).*

<b>Aurora Public Schools</b>	<b>Type</b>	<b>Description</b>	<b>Label</b>	<b>Lead Result ppb = parts per billion</b>
Hinkley HS	DF	Hallway by staff RR W side 1stfl	374-DF-42R	<1
Hinkley HS	DF	Hallway by rm 1110	374-DF-43L	1.10
Hinkley HS	DF	Hallway by rm 1110	374-DF-44R	1.25
Hinkley HS	DF	Hallway by rm 1111	374-DF-45L	1.05
Hinkley HS	DF	Hallway by rm 1111	374-DF-46R	1.10
Hinkley HS	DF	Hallway by staff RR E side 1stfl	374-DF-47L	<1
Hinkley HS	DF	Hallway by staff RR E side 1stfl	374-DF-48R	<1
Hinkley HS	SK	Life skills kitchen area SK1	374-SK-49	<1
Hinkley HS	SK	Life skills kitchen area SK2	374-SK-50	<1
Hinkley HS	SK	Life skills kitchen area SK3	374-SK-51	1.15
Hinkley HS	DF	Boys lckr rm 1639	374-DF-52	<1
Hinkley HS	DF	Varsity lckr rm 1646	374-DF-53	1.85
Hinkley HS	DF	Girls lckr rm 1632	374-DF-54	<1
Hinkley HS	DF	Hallway by rm 1304	374-DF-55L	1.75
Hinkley HS	DF	Hallway by rm 1304	374-DF-56R	1.32
Hinkley HS	SK	Break rm 1364	374-SK-57	1.04
Hinkley HS	BF	Gym lobby area	374-BF-58	<1
Hinkley HS	DF	Gym lobby area	374-DF-59	<1
Hinkley HS	SK	Concession	374-SK-60	1.05
Hinkley HS	DF	DF in weight rm	374-DF-61L	<1
Hinkley HS	WD	Staff lounge 2nd fl	374-WD-62	<1
Hinkley HS	WD	Office area 1st fl	374-WD-63	<1
Hinkley HS	WD	Back office lounge	374-WD-64	<1
Hinkley HS	WD	Staff lounge 1st fl	374-WD-65	<1
Hinkley HS	SK	Classroom 1305	374-SK-66	<1
Hinkley HS	WD	Classroom 1364/break rm	374-WD-67	<1
Hinkley HS	DF	DF in weight rm	374-DF-68R	1.05