

Jewell - Sampled 11/23/16

Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IHD, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK -01, 122- SKB -04).

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Jewell	SK	Food Prep Sink/Kitchen	120-SK-1	<1
Jewell	SK	SK by dishwasher/Kitchen	120-SK-2	<1
Jewell	SK	Clinic	120-SK-3	<1
Jewell	SK	Workroom in office	120-SK-4	5.78
Jewell	DF	Hallway by room K1	120-DF-5	<1
Jewell	SK	Classroom K1	120-SK-6	<1
Jewell	SK	Classroom K2	120-SK-7	<1
Jewell	SK	Classroom 60 Left SK	120-SK-8	<1
Jewell	SK	Classroom 60 Right SK	120-SK-9	<1
Jewell	SKB	Classroom A1	120-SKB-10	<1
Jewell	SKB	Classroom A2	120-SKB-11	<1
Jewell	SKB	Classroom A3	120-SKB-12	<1
Jewell	SKB	Classroom A4	120-SKB-13	<1
Jewell	DF	Hallway b room B1	120-DF-14	<1
Jewell	SKB	Classroom B1	120-SKB-15	1.53
Jewell	SKB	Classroom B2	120-SKB-16	<1
Jewell	SKB	Classroom B3	120-SKB-17	<1
Jewell	SKB	Classroom B4	120-SKB-18	<1
Jewell	SK	ESS room by media center	120-SK-19	6.15
Jewell	DF	Hallway by room C1	120-DF-20	<1
Jewell	SKB	Classroom C1	120-SKB-21	<1
Jewell	SKB	Classroom C2	120-SKB-22	<1
Jewell	SKB	Classroom C3	120-SKB-23	<1
Jewell	SKB	Classroom C4	120-SKB-24	<1
Jewell	SKB	Classroom D1	120-SKB-25	<1
Jewell	SKB	Classroom D2	120-SKB-26	<1
Jewell	SKB	Classroom D3	120-SKB-27	<1
Jewell	SKB	Classroom D4	120-SKB-28	<1
Jewell	SKB	Classroom E3	120-SKB-29	<1
Jewell	SKB	Classroom E4	120-SKB-30	<1
Jewell	SKB	Classroom E2	120-SKB-31	<1
Jewell	SK	Classroom E1	120-SK-32	<1
Jewell	SKB	Staff Lounge	120-SKB-33	1.08
Jewell	SKB	Classroom 62	120-SKB-34	12.81