



Environmental

SUMMARY OF RADON INSPECTION

Site Address: Paris Elementary School
1635 Paris Street
Aurora, CO 80011

Detector#	Location Room	Placement	Retrieval	Result pCi/L
4138427	Cafee 111	10/29/07 10:00	11/01/07 9:00	1.3
4138432	Kitchen J1	10/29/07 10:00	11/01/07 9:00	0.8
4138426	Cust N12	10/29/07 10:00	11/01/07 9:00	0.9
4138436	Gyme SE	10/29/07 10:00	11/01/07 9:00	1.0
4138431	Gym NW	10/29/07 10:00	11/01/07 9:00	1.5
4138435	C17	10/29/07 10:00	11/01/07 9:00	1.3
4138429	Wkrm A16	10/29/07 10:00	11/01/07 9:00	1.3
4135430	Small group A15	10/29/07 10:00	11/01/07 9:00	1.1
4138433	Clinic	10/29/07 10:00	11/01/07 9:00	1.3
4138434	Conf A13	10/29/07 10:00	11/01/07 9:00	1.6
4138421	Prin A12	10/29/07 10:00	11/01/07 9:00	2.5
4138416	Sec A11	10/29/07 10:00	11/01/07 9:00	1.6
4138415	CRC11	10/29/07 10:00	11/01/07 9:00	1.4
4138414	C12	10/29/07 10:00	11/01/07 9:00	2.0
4138419	C13	10/29/07 10:00	11/01/07 9:00	2.8
4138422	C14	10/29/07 10:00	11/01/07 9:00	1.7
4138423	C15	10/29/07 10:00	11/01/07 9:00	1.7
4138420	C16	10/29/07 10:00	11/01/07 9:00	2.0
4138428	Small Grp D11	10/29/07 10:00	11/01/07 9:00	1.1
4138418	Mult Purpose	10/29/07 10:00	11/01/07 9:00	1.2
4138425	Mult Purpose dup	10/29/07 10:00	11/01/07 9:00	1.3 duplicate
4138424	511 res	10/29/07 10:00	11/01/07 9:00	1.3
4138417	EH Wkrm	10/29/07 10:00	11/01/07 9:00	1.2
4138693	Blank	10/29/07 10:00	11/01/07 9:00	<0.3

RECOMMENDATIONS

No additional testing is warranted at this time. All results were below the EPA's action level of 4.0 pCi/L.

Sincerely,


Tammy Linton