

## Side Creek - Sampled 12/9/16

*Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IHD, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK -01, 122- SKB -04).*

<b>Aurora Public Schools</b>	<b>Type</b>	<b>Description</b>	<b>Label</b>	<b>Lead Result ppb = parts per billion</b>
Side Creek	SK	Food Prep Sink/Kitchen	139-SK-1	<1
Side Creek	PF	Pot filler/Kitchen	139-PF-2	<1
Side Creek	DF	Hallway by office	139-DF-3	<1
Side Creek	DF	DF in gym	139-DF-4	<1
Side Creek	SKB	Art Room	139-SKB-5	<1
Side Creek	SK	Staff lounge	139-SK-6	<1
Side Creek	IHD	Staff lounge	139-IHD-7	<1
Side Creek	SKB	Para workroom by rm 54	139-SKB-8	3.39
Side Creek	SKB	Sped room by rm 53	139-SKB-9	2.47
Side Creek	SKB	Classroom 54	139-SKB-10	<1
Side Creek	SKB	Classroom 53	139-SKB-11	1.30
Side Creek	SKB	Classroom 52	139-SKB-12	<1
Side Creek	SKB	Classroom 51	139-SKB-13	<1
Side Creek	SKB	Classroom 44	139-SKB-14	3.36
Side Creek	SKB	Classroom 45	139-SKB-15	1.40
Side Creek	SKB	Classroom 43	139-SKB-16	1.59
Side Creek	SKB	Classroom 42	139-SKB-17	1.66
Side Creek	SKB	Classroom 41	139-SKB-18	1.24
Side Creek	SKB	Classroom 5	139-SKB-19	5.58
Side Creek	SKB	C4 Computer lab	139-SKB-20	2.32
Side Creek	SKB	C3	139-SK-21	11.6
Side Creek	SKB	Classroom C1	139-SKB-22	1.36
Side Creek	SKB	Para workroom by rm 34	139-SKB-23	5.77
Side Creek	SKB	Teacher wrkrm by rm 33	139-SKB-24	8.80
Side Creek	SKB	Classroom 34	139-SKB-25	1.14
Side Creek	SKB	Classroom 33	139-SKB-26	1.28
Side Creek	SKB	Classroom 32	139-SKB-27	<1
Side Creek	SK	Classroom 30	139-SK-28	<1
Side Creek	SKB	Classroom 30	139-SKB-29	<1
Side Creek	SKB	Classroom 31	139-SKB-30	<1
Side Creek	SKB	Classroom 24	139-SKB-31	1.44
Side Creek	SKB	Classroom 25	139-SKB-32	<1
Side Creek	SKB	Classroom 26	139-SKB-33	1.00
Side Creek	SKB	Classroom 23	139-SKB-34	<1
Side Creek	SKB	Classroom 22	139-SKB-35	<1
Side Creek	SKB	Classroom 21	139-SKB-36	1.09
Side Creek	SK	Office in Media Center	139-SK-37	1.12
Side Creek	SKB	Classroom 14	139-SKB-38	2.49
Side Creek	SKB	Classroom 13	139-SKB-39	5.24
Side Creek	SKB	Classroom 1	139-SKB-40	2.16
Side Creek	SK	Classroom 00	139-SK-41	1.48
Side Creek	SKB	Classroom 12	139-SKB-42	2.60

## Side Creek - Sampled 12/9/16

*Source types: Drinking fountain= **DF**, Sink= **SK**, Water Bottle Filler= **BF**, Sink Bubbler= **SKB**, Insta Hot Dispenser= **IHD**, Water Dispenser= **WD**, Pot Filler= **PF** (e.g. 114- **SK** -01, 122- **SKB** -04).*

<b>Aurora Public Schools</b>	<b>Type</b>	<b>Description</b>	<b>Label</b>	<b>Lead Result ppb = parts per billion</b>
Side Creek	SKB	Classroom 11	139-SKB-43	1.83
Side Creek	SKB	Psy/Soc wk room by rm 11	139-SKB-44	19.3
Side Creek	SKB	Psy/Soc wk room by rm 11 resample after replacement.	139-SKB-44C	2.91
Side Creek	SKB	Speech room by rm 11	139-SKB-45	10.9
Side Creek	SKB	Classroom 2	139-SKB-46	3.83
Side Creek	SK	Work room behind office	139-SK-47	<1
Side Creek	IHD	Work room behind office	139-IHD-48	1.02
Side Creek	WD	WD in office	139-WD-49	<1
Side Creek	SKB	Clinic	139-SKB-50	<1
Side Creek	SK	Psy/Soc wk room by rm 11	139-SK-51	14.4