

Sixth Ave - Sampled 11/4/16

Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IHD, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK -01, 122- SKB -04).

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Sixth Avenue	SK	Clinic	140-SK-01	<1
Sixth Avenue	DF	Hallway by custodial closet	140-DF-02R	<1
Sixth Avenue	DF	Hallway by custodial closet	140-DF-03L	<1
Sixth Avenue	SK	Food Prep Sink/Kitchen	140-SK-04	<1
Sixth Avenue	SKB	Classroom 19	140-SKB-05	<1
Sixth Avenue	SK	Classroom 18 SKB not working so tested SK	140-SK-06	1.27
Sixth Avenue	SKB	Classroom 26	140-SKB-07	<1
Sixth Avenue	DF	Hallway between 19 & 17	140-DF-08R	<1
Sixth Avenue	DF	Hallway between 19 & 17	140-DF-09L	<1
Sixth Avenue	SKB	Classroom 17	140-SKB-10	<1
Sixth Avenue	SKB	Classroom 11	140-SKB-11	<1
Sixth Avenue	SKB	Classroom 10	140-SKB-12	<1
Sixth Avenue	SKB	Classroom 8	140-SKB-13	<1
Sixth Avenue	SKB	Classroom 7	140-SKB-14	<1
Sixth Avenue	SKB	Classroom 6	140-SKB-15	<1
Sixth Avenue	SKB	Classroom 5	140-SKB-16	<1
Sixth Avenue	SKB	Classroom 4	140-SKB-17	1.99
Sixth Avenue	SKB	Classroom 3	140-SKB-18	<1
Sixth Avenue	SK	Classroom 2	140-SK-19	14.8
Sixth Avenue	SK	Classroom 2 resample after replacement	140-SK-19D	4.81
Sixth Avenue	SKB	Classroom 28	140-SKB-20	<1
Sixth Avenue	SK	Classroom 27	140-SK-21	<1
Sixth Avenue	SKB	Classroom 1/Music	140-SKB-22	<1
Sixth Avenue	DF	Classroom 9/Art	140-DF-23	<1
Sixth Avenue	SK	Small group D3	140-SK-24	9.56
Sixth Avenue	SKB	Classroom 12	140-SKB-25	<1
Sixth Avenue	SKB	Classroom 13	140-SKB-26	<1
Sixth Avenue	SK	Classroom 14 SKB not working so tested SK	140-SK-27	<1
Sixth Avenue	SKB	Classroom 15	140-SKB-28	<1
Sixth Avenue	SKB	Classroom 16	140-SKB-29	<1
Sixth Avenue	SKB	Classroom 25	140-SKB-30	1.21
Sixth Avenue	SKB	Classroom 24	140-SKB-31	<1
Sixth Avenue	SKB	Classroom 23	140-SKB-32	<1
Sixth Avenue	SKB	Classroom 22	140-SKB-33	<1
Sixth Avenue	SKB	Classroom 21	140-SKB-34	<1
Sixth Avenue	DF	Hallway by RR	140-DF-35	<1
Sixth Avenue	SK	Staff Lounge	140-SK-36	<1
Sixth Avenue	IHD	Staff Lounge	140-IHD-37	<1