

## South MS - Sampled 2/10/17

*Source types: Drinking fountain= **DF**, Sink= **SK**, Water Bottle Filler= **BF**, Sink Bubbler= **SKB**, Insta Hot Dispenser= **IHD**, Water Dispenser= **WD**, Pot Filler= **PF** (e.g. 114- **SK**-01, 122- **SKB** -04).*

<b>Aurora Public Schools</b>	<b>Type</b>	<b>Description</b>	<b>Label</b>	<b>Lead Result ppb = parts per billion</b>
South MS	DF	Lobby by counseling	258-DF-1	<1
South MS	SK	Clinic bathroom	258-SK-2	<1
South MS	SK	Clinic/eyewash attached	258-SK-3	<1
South MS	IHD	Staff Lounge	258-IHD-4	<1
South MS	SK	Staff Lounge	258-SK-5	<1
South MS	DF	Hallway by Rm B8	258-DF-6	<1
South MS	SK	Classroom B2	258-SK-7	<1
South MS	DF	Hallway by Rm C1	258-DF-8	<1
South MS	SK	Classroom C2	258-SK-9	<1
South MS	SK	Classroom C7 SK1	258-SK-10	<1
South MS	SK	Classroom C7 SK2	258-SK-11	<1
South MS	SK	Classroom C7 SK3	258-SK-12	14.9
South MS	SK	Classroom C7 SK3 resample after replacement and flush	258-SK-12C	3.50
South MS	SK	Classroom C7 SK4	258-SK-13	12.5
South MS	SK	Classroom C3	258-SK-14	<1
South MS	SK	Classroom C5	258-SK-15	<1
South MS	SK	Food Prep Sink/Kitchen	258-SK-16	<1
South MS	PF	Pot Filler/Kitchen	258-PF-17	<1
South MS	DF	Hallway by Gym	258-DF-18L	<1
South MS	DF	Hallway by Gym	258-DF-19R	<1
South MS	DF	Hallway by rm D23	258-DF-20L	<1
South MS	DF	Hallway by rm D23 Right DF not attached so not tested		
South MS	SK	Classroom D23	258-SK-22	<1
South MS	SK	Office in media center	258-SK-23	<1
South MS	DF	DF in media center	258-DF-24	<1
South MS	SK	AV office in media center	258-SK-25	<1
South MS	DF	Hallway by rm E15	258-DF-26	<1
South MS	SK	Classroom E15	258-SK-27	<1
South MS	DF	Hallway by F2	258-DF-28	<1
South MS	SK	Lifeskills rm SK1	258-SK-29	<1
South MS	SK	Lifeskills rm SK2	258-SK-30	<1
South MS	SK	Classroom F2	258-SK-31	<1
South MS	DF	Lifeskills DF	258-DF-32	<1