

DAMES & MOORE

1125 SEVENTEENTH STREET, SUITE 1200
DENVER, COLORADO 80202AURORA PUBLIC SCHOOLS
RADON INVESTIGATION DATA SHEETS

Det. #	School	Date Set	Date Retrtd.	Location	Comments	pCi/liter	Error +/-
13755	Vassar	18-Apr-90	11-Apr-91	Clinic	Wiremold to call button	0	0.4
13756	Vassar	18-Apr-90	16-Apr-91	Principals office	T-stat	0	0.3
13757	Vassar	18-Apr-90	11-Apr-91	Asst. principals office	Wiremold to outlet-east wall	0	0.4
13758	Vassar	18-Apr-90	11-Apr-91	Secretarys office	Near fire panel	0.1	0.4
13759	Vassar	18-Apr-90	11-Apr-91	Office workroom	Emergency light	0.5	0.5
13760	Vassar	18-Apr-90	11-Apr-91	Cafeteria	Motion detector S-W corner	0.4	0.5
13761	Vassar	18-Apr-90	11-Apr-91	Cafeteria	Light fixture ctnr of room	0	0.4
13762	Vassar	18-Apr-90	11-Apr-91	Teachers lounge	Permanent cabinet over sink	0	0.4
13763	Vassar	18-Apr-90	11-Apr-91	Print shop	Wiremold west wall	0.3	0.5
13764	Vassar	18-Apr-90	11-Apr-91	Kitchen	Motion detector	0	0.4
13765	Vassar	18-Apr-90	12-Apr-91	Classroom K1	QA to 13766	0.5	0.5
13766	Vassar	18-Apr-90	12-Apr-91	Classroom K1	Movie scrn brkts, QA is 13765	0	0.4
13767	Vassar	18-Apr-90	11-Apr-91	Classroom 41	Emergency light, QA is 13768	0	0.4
13768	Vassar	18-Apr-90	11-Apr-91	Classroom 41	QA to 13767	0	0.4
13769	Vassar	18-Apr-90	11-Apr-91	Classroom 42	Wiremold to call button	0	0.4
13770	Vassar	18-Apr-90	11-Apr-91	Workroom 4-A	Permanent cabinet west wall	0	0.4
13771	Vassar	18-Apr-90	11-Apr-91	Classroom 43	South wall	0	0.4
13772	Vassar	18-Apr-90	11-Apr-91	Teacher workroom rm 63	Chalk board bracket-west wall	0	0.4
13773	Vassar	18-Apr-90	11-Apr-91	Classroom 31	Emergency light	0	0.4
13774	Vassar	18-Apr-90	11-Apr-91	Classroom 34	Chalk board bracket-west wall	0	0.4
13775	Vassar	18-Apr-90	11-Apr-91	Classroom 32	Chalk board bracket-east wall	0.9	0.5
13776	Vassar	18-Apr-90	11-Apr-91	Classroom 33	Above cabinet east wall	0	0.4
13777	Vassar	18-Apr-90	11-Apr-91	Work room 3-A	Permanent cabinet north wall	0.3	0.5
13778	Vassar	18-Apr-90	12-Apr-91	Custodial office	Conduit to LIC panel	0	0.4
13779	Vassar	18-Apr-90	11-Apr-91	Classroom 22	East wall by window	0	0.4
13780	Vassar	18-Apr-90	11-Apr-91	Workroom 2A	Permanent cabinet south wall	0.6	0.5
13781	Vassar	18-Apr-90	11-Apr-91	Classroom 23	Wall abv perm.cab. -S.E. cab	1.7	0.5
13782	Vassar	18-Apr-90	11-Apr-91	Classroom 25	Emergency lights	0.2	0.4
13783	Vassar	18-Apr-90	11-Apr-91	Classroom 21	Map brkt E wall, QA is 13784	0	0.4
13784	Vassar	18-Apr-90	11-Apr-91	Classroom 21	QA to 13783	0	0.4
13785	Vassar	18-Apr-90	11-Apr-91	Classroom 24	Emergency lights-west wall	0.1	0.4
13786	Vassar	18-Apr-90	11-Apr-91	Work room 1B	West wall	0	0.4
13787	Vassar	18-Apr-90	11-Apr-91	Classroom 14 - 6 Kinder	Emergency lights	0.9	0.5
13788	Vassar	18-Apr-90	11-Apr-91	Classroom 11-3 Kinder	Emergency lights	0.4	0.5
13789	Vassar	18-Apr-90	11-Apr-91	Classroom 12	Wall abv perm. cab. NW corner	0.1	0.4
13790	Vassar	18-Apr-90	11-Apr-91	Classroom 13 5 - Kinder	N. wall abv teachers desk	0.7	0.5
13791	Vassar	18-Apr-90	11-Apr-91	Media Center office	Permanent cabinet - s. wall	0	0.4
13792	Vassar	18-Apr-90	11-Apr-91	Media Center/Computer Rm	Wiremold to computer swt.w.wall	0	0.4

Note: Shaded area denotes values over 4.0 pCi/liter

DAMES & MOORE

1125 SEVENTEENTH STREET, SUITE 1200
DENVER, COLORADO 80202

AURORA PUBLIC SCHOOLS
RADON INVESTIGATION DATA SHEETS

Det. #	School	Date Set	Date Retrtd.	Location	Comments	pCi/liter	Error +/-
13793	Vassar	18-Apr-90	11-Apr-91	Art room	Hk in cling N wall, QA is 13794	0	0.4
13794	Vassar	18-Apr-90	11-Apr-91	Art room	QA to 13793	0.5	0.5
13795	Vassar	18-Apr-90	11-Apr-91	Classroom K2 - <i>Pre-K</i>	Map bracket west wall	0.7	0.5
13796	Vassar	18-Apr-90	12-Apr-91	Boiler room	Conduit to compressor switch	0	0.4
13797	Vassar	18-Apr-90	12-Apr-91	S. Mobile classroom	light conduit N-E end	0	0.4
13798	Vassar	18-Apr-90	12-Apr-91	Mobile classroom 55	I-hook bet closet doors/w-wall	0	0.4
13799	Vassar	18-Apr-90	12-Apr-91	Mobile classroom 54	I-hook bet closet doors/e-wall	0	0.4
13800	Vassar	18-Apr-90	11-Apr-91	Workroom 1-A	Permanent cabinet	0.6	0.5
13801	Vassar	18-Apr-90	11-Apr-91	Media Center	Emergency lights - west wall	1	0.5
13802	Vassar	18-Apr-90	11-Apr-91	Media Center	Elect. cord extension reel	0	0.4
13803	Vassar	18-Apr-90	12-Apr-91	Music room	Emergency light	0	0.4
13804	Vassar	18-Apr-90	12-Apr-91	PE office	Wiremold to speaker	0	0.4
13805	Vassar	18-Apr-90	12-Apr-91	Gymnasium	Clock	0	0.4
13806	Vassar	18-Apr-90	12-Apr-91	Gymnasium	Emergency lights - west wall	0	0.4
13807	Vassar	18-Apr-90	12-Apr-91	Classroom 53	Emergency lights	0	0.4
13808	Vassar	18-Apr-90	12-Apr-91	Classroom 52	Call btn wiremold/QA is 13809	0	0.4
13809	Vassar	18-Apr-90	12-Apr-91	Classroom 52	QA to 13808	0	0.4
13810	Vassar	18-Apr-90	11-Apr-91	Classroom 45	Emergency light	0	0.4
13811	Vassar	18-Apr-90	11-Apr-91	Classroom 51	Map bracket west wall	0	0.4
13812	Vassar	18-Apr-90	11-Apr-91	Workroom 5-B	West wall	0.1	0.4
13813	Vassar	18-Apr-90	11-Apr-91	Workroom 4-B	West wall	0	0.4
13814	Vassar	18-Apr-90	11-Apr-91	Classroom 44	Map bracket north wall	0	0.4
14892	Vassar	18-Apr-90	11-Apr-91	Shipping QA	Shipping QA	1.4	0.4

Note: Shaded area denotes values over 4.0 pCi/liter