

## Vaughn - Sampled 11/4/16

*Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IHD, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK -01, 122- SKB -04).*

<b>Aurora Public Schools</b>	<b>Type</b>	<b>Description</b>	<b>Label</b>	<b>Lead Result ppb = parts per billion</b>
Vaughn	SK	Food Prep Sink/Kitchen	142-SK-01	<1
Vaughn	DF	Hallway by cafeteria	142-DF-02L	<1
Vaughn	DF	Hallway by cafeteria	142-DF-03R	<1
Vaughn	SK	Classroom 109	142-SK-04	4.10
Vaughn	SK	Classroom 110	142-SK-05	<1
Vaughn	SK	Classroom 111	142-SK-06	2.98
Vaughn	SK	Classroom 112	142-SK-07	<1
Vaughn	SK	Classroom 113	142-SK-08	1.71
Vaughn	SK	Computer lab	142-SK-09	<1
Vaughn	SK	Staff Lounge	142-SK-10	<1
Vaughn	SK	Office in Media Center	142-SK-11	1.02
Vaughn	DF	Classroom 119	142-DF-12	2.44
Vaughn	SK	Classroom 123	142-SK-13	<1
Vaughn	SK	Classroom 173	142-SK-14	<1
Vaughn	SK	Clinic	142-SK-15	<1
Vaughn	SK	Conference room	142-SK-16	<1
Vaughn	SK	Classroom 135	142-SK-17	<1
Vaughn	SK	Classroom 136	142-SK-18	<1
Vaughn	SK	Classroom 137	142-SK-19	1.26
Vaughn	SK	Classroom 138	142-SK-20	1.25
Vaughn	SK	Classroom 139	142-SK-21	<1
Vaughn	SKB	Classroom 141	142-SKB-22	14.2
Vaughn	SKB	Classroom 141 resample after replacement	142-SKB-22C	<1
Vaughn	SK	Art Room	142-SK-23	<1
Vaughn	SK	Resource Room 161	142-SK-24	2.22
Vaughn	DF	Hallway by custodial closet	142-DF-25L	<1
Vaughn	DF	Hallway by custodial closet	142-DF-26R	<1
Vaughn	SK	Workroom next to 161	142-SK-27	<1
Vaughn	SK	Classroom 167	142-SK-28	<1
Vaughn	SK	Classroom 166	142-SK-29	2.67
Vaughn	SK	Classroom 169	142-SK-30	1.88
Vaughn	SK	Classroom 168	142-SK-31	<1
Vaughn	SKB	Classroom 172	142-SKB-32	<1
Vaughn	SK	Classroom 171	142-SK-33	4.17
Vaughn	SK	Classroom 141	142-SK-34	2.07