

Vista Peak HS - Sampled 4/14/17

Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IHD, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK-01, 122- SKB-04).

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Vista Peak HS	DF	Hallway by kitchen	362-DF-1R	<1
Vista Peak HS	DF	Hallway by kitchen	362-DF-2L	<1
Vista Peak HS	PF	Pot filler/kitchen	362-PF-3	1.15
Vista Peak HS	SK	Food Prep Sink/Kitchen	362-SK-4	<1
Vista Peak HS	SK	Custodial office 1006	362-SK-5	<1
Vista Peak HS	DF	Boys PE lckr rm 1103	362-DF-6	1.15
Vista Peak HS	DF	Boys varsity lckr rm 1106	362-DF-7	<1
Vista Peak HS	SK	Trainer room 1107	362-SK-8	<1
Vista Peak HS	DF	Girls varsity lckr rm 1108 Not working so not tested		
Vista Peak HS	DF	Girls PE lckr rm 1111	362-DF-10	<1
Vista Peak HS	DF	Aux gym entrance 1112	362-DF-11L	<1
Vista Peak HS	DF	Aux gym entrance 1112	362-DF-12R	<1
Vista Peak HS	DF	Main gym entrance 1101	362-DF-13L	<1
Vista Peak HS	DF	Main gym entrance 1101	362-DF-14R	<1
Vista Peak HS	DF	Classroom 1206/Drama	362-DF-15	<1
Vista Peak HS	DF	Classroom 1302/Vocal	362-DF-16	<1
Vista Peak HS	DF	Classroom 1309/Band	362-DF-17	<1
Vista Peak HS	SK	Kitchen area by 1015	362-SK-18	<1
Vista Peak HS	DF	Main lobby	362-DF-19L	<1
Vista Peak HS	DF	Main lobby	362-DF-20R	<1
Vista Peak HS	SK	Clinic	362-SK-21	2.78
Vista Peak HS	DF	Hallway in office area	362-DF-22L	<1
Vista Peak HS	DF	Hallway in office area	362-DF-23R	<1
Vista Peak HS	SK	Wrkrm 1025/office area	362-SK-24	<1
Vista Peak HS	DF	Hallway by rm 1403	362-DF-25R	<1
Vista Peak HS	DF	Hallway by rm 1403	362-DF-26L	<1
Vista Peak HS	SK	Teacher offices 1421	362-SK-27	<1
Vista Peak HS	DF	Hallway by rm 1408	362-DF-28R	<1
Vista Peak HS	DF	Hallway by rm 1408	362-DF-29L	<1
Vista Peak HS	SK	Life skills rm 1501 SK1	362-SK-30	1.98
Vista Peak HS	SK	Life skills rm 1501 SK2	362-SK-31	1.26
Vista Peak HS	DF	Hallway by rm 1503	362-DF-32R	<1
Vista Peak HS	DF	Hallway by rm 1503	362-DF-33L	<1
Vista Peak HS	SK	Teacher offices 1521	362-SK-34	1.15
Vista Peak HS	DF	Hallway by rm 1508	362-DF-35R	<1
Vista Peak HS	DF	Hallway by rm 1508	362-DF-36L	<1
Vista Peak HS	DF	Weight rm 2101 mezzanine	362-DF-37	<1
Vista Peak HS	SK	School store	362-SK-38	3.36
Vista Peak HS	SK	Wrkrm 2005	362-SK-39	<1
Vista Peak HS	DF	DF in media center	362-DF-40L	<1

Vista Peak HS - Sampled 4/14/17

*Source types: Drinking fountain= **DF**, Sink= **SK**, Water Bottle Filler= **BF**, Sink Bubbler= **SKB**, Insta Hot Dispenser= **IHD**, Water Dispenser= **WD**, Pot Filler= **PF** (e.g. 114- **SK** -01, 122- **SKB** -04).*

Aurora Public Schools	Type	Description	Label	Lead Result ppb = parts per billion
Vista Peak HS	DF	DF in media center	362-DF-41R	<1
Vista Peak HS	SK	Wrkrm in media center 2406	362-SK-42	2.46
Vista Peak HS	DF	Hallway by ceramics	362-DF-43	<1
Vista Peak HS	SK	Art office 2411	362-SK-44	<1
Vista Peak HS	DF	Hallway by RR	362-DF-45L	<1
Vista Peak HS	DF	Hallway by RR	362-DF-46R	<1
Vista Peak HS	DF	Hallway by rm 2504	362-DF-47R	<1
Vista Peak HS	DF	Hallway by rm 2504	362-DF-48L	<1
Vista Peak HS	SK	Teacher offices 2522	362-SK-49	1.42
Vista Peak HS	DF	Hallway by rm 2509	362-DF-50R	<1
Vista Peak HS	DF	Hallway by rm 2509	362-DF-51L	<1
Vista Peak HS	SK	Life skills rm 1406 SK1	362-SK-52	1.92
Vista Peak HS	SK	Life skills rm 1406 SK2	362-SK-53	1.38
Vista Peak HS	DF	Hallway by gym	362-DF-54L	<1
Vista Peak HS	DF	Hallway by gym	362-DF-55R	<1