



RDS

Environmental

SUMMARY OF RADON INSPECTION

Site Address:

William Smith High School
400 Airport Blvd
Denver, CO 80011

Detector#	Location Room	Placement	Retrieval	Result pCi/L
4138724	CR139	10/29 8:00am	11/01 8:00 am	0.7
4138722	Bus Tech	10/29 8:00am	11/01 8:00 am	0.8
4138702	CR 148	10/29 8:00am	11/01 8:00 am	1.6
4138727	Nursery 150	10/29 8:00am	11/01 8:00 am	0.6
4138726	Crawler Sleeping	10/29 8:00am	11/01 8:00 am	0.5
4138725	CS Nursing 152	10/29 8:00am	11/01 8:00 am	1.9
4138728	Walk nurs 153	10/29 8:00am	11/01 8:00 am	2.3
4138729	Tod nurs 154	10/29 8:00am	11/01 8:00 am	1.6
4138730	135	10/29 8:00am	11/01 8:00 am	0.6
4138733	133 Media	10/29 8:00am	11/01 8:00 am	1.0
4138732	Hart office 183	10/29 8:00am	11/01 8:00 am	0.7
4138731	Hart CR 182	10/29 8:00am	11/01 8:00 am	0.8
4138735	Hart Cr 181	10/29 8:00am	11/01 8:00 am	0.7
4138734	Commons SW	10/29 8:00am	11/01 8:00 am	0.9
4138736	Commons NE	10/29 8:00am	11/01 8:00 am	0.6
4138738	Science Cr 175	10/29 8:00am	11/01 8:00 am	1.2
4138739	Science Cr 174	10/29 8:00am	11/01 8:00 am	1.6
4138703	Art	10/29 8:00am	11/01 8:00 am	1.3
4138745	Nursery Stor 160	10/29 8:00am	11/01 8:00 am	0.8
4138743	Nurs Off 156	10/29 8:00am	11/01 8:00 am	0.9
4138742	Nurs Off 156	10/29 8:00am	11/01 8:00 am	0.7 duplicate
4138696	Blank	10/29 8:00am	11/01 8:00 am	<0.3
4138704	Wkrm 110	10/29 7:35	11/01/07 8:00	0.5
4138710	Lounge	10/29 7:35	11/01/07 8:00	0.6
4138708	105 Asst. Princ	10/29 7:35	11/01/07 8:00	1.2
4138709	107 Prc Office	10/29 7:35	11/01/07 8:00	1.0
4138706	103 Main Office	10/29 7:35	11/01/07 8:00	0.8
4138707	113	10/29 7:35	11/01/07 8:00	0.5
4138712	115	10/29 7:35	11/01/07 8:00	0.8
4138711	116	10/29 7:35	11/01/07 8:00	<0.3
4138715	CR118	10/29 7:35	11/01/07 8:00	3.6
4138713	CR 119	10/29 7:35	11/01/07 8:00	1.3
4138714	CR 120	10/29 7:35	11/01/07 8:00	1.7
4138716	CR121	10/29 7:35	11/01/07 8:00	1.3
4134146	CR123	10/29 7:35	11/01/07 8:00	3.2

4138719	CR124	10/29 7:35	11/01/07 8:00	5.2 (Elevated)
4138721	Seminar 125	10/29 7:35	11/01/07 8:00	1.2
4138701	CR130	10/29 7:35	11/01/07 8:00	2.2
4138717	CR131	10/29 7:35	11/01/07 8:00	1.2
4138718	CR132	10/29 7:35	11/01/07 8:00	1.4
4138720	Office 137	10/29 7:35	11/01/07 8:00	1.2
4138723	CR 138	10/29/07 8:00	11/01/07 8:00	1.2
4138737	CR 138 dup	10/29/07 8:00	11/01/07 8:00	1.1 duplicate
4138741	Director 157	10/29/07 8:00	11/01/07 8:00	0.5
4138744	Nurse 158	10/29/07 8:00	11/01/07 8:00	0.8
4138740	Sem 166	10/29/07 8:00	11/01/07 8:00	0.5

RECOMMENDATIONS

Long term testing is recommended within Room CR124. All other rooms indicated radon levels below the EPA action guideline of 4.0 pCi/l. Please call us should you have any questions.

Sincerely,


 Tammy Linton