

Pickens Tech - Sampled 4/21/2017

Source types: Drinking fountain= DF, Sink= SK, Water Bottle Filler= BF, Sink Bubbler= SKB, Insta Hot Dispenser= IDH, Water Dispenser= WD, Pot Filler= PF (e.g. 114- SK -01, 122- SKB -04).

Aurora Public Schools	Type	Description	Label	Leac Result ppb = parts per billion
Pickens Tech	SK	Staff lounge bldg B	477-SK-1	<1
Pickens Tech	WD	Staff lounge bldg B	477-WD-2	<1
Pickens Tech	DF	B160 Diesel Mechanics	477-DF-3	1.50
Pickens Tech	DF	Hallway by custodial closet	477-DF-4	<1
Pickens Tech	DF	Classroom B180 HVAC	477-DF-5	1.31
Pickens Tech	DF	Classroom B185 HVAC	477-DF-6	2.79
Pickens Tech	DF	Hallway across from B130	477-DF-7	<1
Pickens Tech	SK	Classroom B123	477-SK-8	3.62
Pickens Tech	SK	Classroom B115 right SK	477-SK-9	2.27
Pickens Tech	SK	Classroom B115 left SK	477-SK-10	2.46
Pickens Tech	DF	Lower Auto Mech	477-DF-11	1.80
Pickens Tech	DF	Upper Auto Mech	477-DF-12	<1
Pickens Tech	DF	Welding	477-DF-13	<1
Pickens Tech	DF	Collision repair	477-DF-14	<1
Pickens Tech	SK	A1.52 Hospitality	477-SK-15	<1
Pickens Tech	DF	Hallway by RRs	477-DF-16	<1
Pickens Tech	SK	A1.48 culinary SK1	477-SK-17	1.44
Pickens Tech	SK	A1.48 culinary SK2	477-SK-18	<1
Pickens Tech	PF	A1.48 culinary pot filler	477-PF-19	5.26
Pickens Tech	WD	Staff lounge	477-WD-20	<1
Pickens Tech	SK	Staff lounge	477-SK-21	<1
Pickens Tech	SK	Kitchen	477-SK-22	<1
Pickens Tech	WD	Back of main office	477-WD-23	<1
Pickens Tech	SK	Back of main office	477-SK-24	<1
Pickens Tech	SK	A1.207 toddler rm	477-SK-25	<1
Pickens Tech	SK	A1.207 toddler rm	477-SK-26	<1
Pickens Tech	SK	A1.212 Pre-K	477-SK-27	<1
Pickens Tech	SK	A1.202 Preschool	477-SK-28	<1
Pickens Tech	SK	Kid's tech kitchen	477-SK-29	<1
Pickens Tech	SK	A1.183 Kid's tech	477-SK-30	<1
Pickens Tech	SK	A1.178 Kid's tech	477-SK-31	<1
Pickens Tech	DF	Hallway across from cosmo	477-DF-32L	<1
Pickens Tech	DF	Hallway across from cosmo	477-DF-33R	<1
Pickens Tech	DF	Bldg D A120	477-DF-34	<1
Pickens Tech	DF	Bldg E by RRs	477-DF-35	<1
Pickens Tech	DF	Hallway by GED office	477-DF-36L	<1
Pickens Tech	DF	Hallway by GED office	477-DF-37R	<1
Pickens Tech	DF	Bldg C Horticulture lab	477-DF-38	<1
Pickens Tech	SK	Bldg C Horticulture lab	477-SK-39	<1
Pickens Tech	SK	Clinic	477-SK-40	<1