

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 1017, 1159
NRSB Device Code 10302,10320

Laboratory Report for:

Property Tested:

Aurora Public Schools Environmental
1369 Airport Boulevard
Aurora CO 80011


Dartmouth Elementary
3050 South Laredo Street
Aurora CO 80013


Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
2048850	546040	02/13/2017 8:00 am	02/15/2017 7:30 am	Custodial Office	1.6
2048851	546041	02/13/2017 8:00 am	02/15/2017 7:30 am	Custodial Office Duplicate	1.6
2048852	546042	02/13/2017 8:00 am	02/15/2017 7:30 am	Main Office Workroom	0.9
2048853	546043	02/13/2017 8:00 am	02/15/2017 7:30 am	Principal Office	0.8
2048854	546044	02/13/2017 8:00 am	02/15/2017 7:30 am	Main Office- Secretary	1.2
2048855	546045	02/13/2017 8:00 am	02/15/2017 7:30 am	Main Office- Conference Room	0.7
2048856	546046	02/13/2017 8:00 am	02/15/2017 7:30 am	CR1	1.9
2048857	546047	02/13/2017 8:00 am	02/15/2017 7:30 am	CR2	2.2
2048858	546048	02/13/2017 8:00 am	02/15/2017 7:30 am	CR3	2.2
2048859	546049	02/13/2017 8:00 am	02/15/2017 7:30 am	1-3 Workroom	2.2

Comment: A copy of this report was emailed to bawalker@aps.k12.co.us.

Distributed by: National Safety Products

Date Received: 02/21/2017 Date Logged: 02/21/2017 Date Analyzed: 02/21/2017 Date Reported: 02/21/2017

Report Reviewed By: 

Report Approved By: 

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 1017, 1159
NRSB Device Code 10302,10320

Laboratory Report for:

Property Tested:

Aurora Public Schools Environmental
1369 Airport Boulevard
Aurora CO 80011

Dartmouth Elementary
3050 South Laredo Street
Aurora CO 80013

Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
2048860	546050	02/13/2017 8:00 am	02/15/2017 7:30 am	1-3 Workroom Duplicate	2.3
2048861	546051	02/13/2017 8:00 am	02/15/2017 7:30 am	CR4	1.1
2048862	546052	02/13/2017 8:00 am	02/15/2017 7:30 am	CR4-5 Workroom	0.8
2048863	546053	02/13/2017 8:00 am	02/15/2017 7:30 am	CR5	0.8
2048864	546054	02/13/2017 8:00 am	02/15/2017 7:30 am	CR6	0.7
2048865	546055	02/13/2017 8:00 am	02/15/2017 7:30 am	CR7	0.9
2048866	546056	02/13/2017 8:00 am	02/15/2017 7:30 am	CR8	1.1
2048867	546057	02/13/2017 8:00 am	02/15/2017 7:30 am	6-8 Workroom	0.9
2048868	546058	02/13/2017 8:00 am	02/15/2017 7:30 am	CR9	2.1
2048869	546059	02/13/2017 8:00 am	02/15/2017 7:30 am	CR10	2.0

Comment: A copy of this report was emailed to bawalker@aps.k12.co.us.

Distributed by: National Safety Products

Date Received: 02/21/2017 Date Logged: 02/21/2017 Date Analyzed: 02/21/2017 Date Reported: 02/21/2017

Report Reviewed By:

Report Approved By:

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 1017, 1159
NRSB Device Code 10302,10320

Laboratory Report for:

Property Tested:

Aurora Public Schools Environmental
1369 Airport Boulevard
Aurora CO 80011


Dartmouth Elementary
3050 South Laredo Street
Aurora CO 80013


Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
2048870	546060	02/13/2017 8:00 am	02/15/2017 7:30 am	CR10 Duplicate	2.4
2048871	546061	02/13/2017 8:00 am	02/15/2017 7:30 am	CR11	2.3

Comment: A copy of this report was emailed to bawalker@aps.k12.co.us.

Distributed by: National Safety Products

Date Received: 02/21/2017 Date Logged: 02/21/2017 Date Analyzed: 02/21/2017 Date Reported: 02/21/2017

Report Reviewed By: 

Report Approved By: 

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.