

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 1017, 1159
NRSB Device Code 10302,10320

Laboratory Report for:

Property Tested:

Aurora Public Schools Environmental
1369 Airport Boulevard
Aurora CO 80011


Dartmouth Elementary
3050 South Laredo Street
Aurora CO 80013


Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
2048964	546062	02/13/2017 8:00 am	02/15/2017 7:30 am	9-11 Workroom	1.8
2048965	546063	02/13/2017 8:00 am	02/15/2017 7:30 am	Media South	4.1
2048966	546064	02/13/2017 8:00 am	02/15/2017 7:30 am	Media North	4.6
2048967	546065	02/13/2017 8:00 am	02/15/2017 7:30 am	Media Office	4.2
2048968	546066	02/13/2017 8:00 am	02/15/2017 7:30 am	CR12	2.7
2048969	546067	02/13/2017 8:00 am	02/15/2017 7:30 am	CR13	2.8
2048970	546068	02/13/2017 8:00 am	02/15/2017 7:30 am	CR14	2.0
2048971	546069	02/13/2017 8:00 am	02/15/2017 7:30 am	12-14 Workroom	1.9
2048972	546070	02/13/2017 8:00 am	02/15/2017 7:30 am	12-14 Workroom Duplicate	2.0
2048973	546071	02/13/2017 8:00 am	02/15/2017 7:30 am	CR15	2.3

Comment: A copy of this report was emailed to bawalker@aps.k12.co.us.

Distributed by: National Safety Products

Date Received: 02/22/2017 Date Logged: 02/22/2017 Date Analyzed: 02/22/2017 Date Reported: 02/22/2017

Report Reviewed By: 

Report Approved By: 

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 1017, 1159
NRSB Device Code 10302,10320

Laboratory Report for:

Property Tested:

Aurora Public Schools Environmental
1369 Airport Boulevard
Aurora CO 80011

Dartmouth Elementary
3050 South Laredo Street
Aurora CO 80013

Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
2048974	546072	02/13/2017 8:00 am	02/15/2017 7:30 am	CR16	2.4
2048975	546073	02/13/2017 8:00 am	02/15/2017 7:30 am	CR17	2.3
2048976	546074	02/13/2017 8:00 am	02/15/2017 7:30 am	15-17 Workroom	2.1
2048977	546075	02/13/2017 8:00 am	02/15/2017 7:30 am	CR31	3.5
2048978	546076	02/13/2017 8:00 am	02/15/2017 7:30 am	CR30	4.9
2048979	546077	02/13/2017 8:00 am	02/15/2017 7:30 am	Para Workroom	4.0
2048980	546078	02/13/2017 8:00 am	02/15/2017 7:30 am	Lounge	4.9
2048981	546079	02/13/2017 8:00 am	02/15/2017 7:30 am	CR27	4.5
2048982	546080	02/13/2017 8:00 am	02/15/2017 7:30 am	CR27 Duplicate	4.4
2048983	546081	02/13/2017 8:00 am	02/15/2017 7:30 am	CR26	3.4

Comment: A copy of this report was emailed to bawalker@aps.k12.co.us.

Distributed by: National Safety Products

Date Received: 02/22/2017 Date Logged: 02/22/2017 Date Analyzed: 02/22/2017 Date Reported: 02/22/2017

Report Reviewed By:

Report Approved By:

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 1017, 1159
NRSB Device Code 10302,10320

Laboratory Report for:

Property Tested:

Aurora Public Schools Environmental
1369 Airport Boulevard
Aurora CO 80011

Dartmouth Elementary
3050 South Laredo Street
Aurora CO 80013

Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
2048984	546082	02/13/2017 8:00 am	02/15/2017 7:30 am	CR25	2.3
2048985	546083	02/13/2017 8:00 am	02/15/2017 7:30 am	RM28	3.7
2048986	546084	02/13/2017 8:00 am	02/15/2017 7:30 am	25 Workroom	3.4
2048987	546085	02/13/2017 8:00 am	02/15/2017 7:30 am	24 Workroom	2.7
2048988	546086	02/13/2017 8:00 am	02/15/2017 7:30 am	CR24	1.5
2048989	546087	02/13/2017 8:00 am	02/15/2017 7:30 am	CR23	1.6
2048990	546088	02/13/2017 8:00 am	02/15/2017 7:30 am	CR22	1.5
2048991	546089	02/13/2017 8:00 am	02/15/2017 7:30 am	RM29	2.0
2048992	546090	02/13/2017 8:00 am	02/15/2017 7:30 am	RM29 Duplicate	2.1
2048993	546091	02/13/2017 8:00 am	02/15/2017 7:30 am	CR21	1.8

Comment: A copy of this report was emailed to bawalker@aps.k12.co.us.

Distributed by: National Safety Products

Date Received: 02/22/2017 Date Logged: 02/22/2017 Date Analyzed: 02/22/2017 Date Reported: 02/22/2017

Report Reviewed By:

Report Approved By:

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 1017, 1159
NRSB Device Code 10302,10320

Laboratory Report for:

Property Tested:

Aurora Public Schools Environmental
1369 Airport Boulevard
Aurora CO 80011

Dartmouth Elementary
3050 South Laredo Street
Aurora CO 80013

Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
2048994	546092	02/13/2017 8:00 am	02/15/2017 7:30 am	CR20	1.2
2048995	546093	02/13/2017 8:00 am	02/15/2017 7:30 am	CR19	4.5
2048996	546094	02/13/2017 8:00 am	02/15/2017 7:30 am	CR18	4.4
2048997	546095	02/13/2017 8:00 am	02/15/2017 7:30 am	Gym East	3.0
2048998	546096	02/13/2017 8:00 am	02/15/2017 7:30 am	Gym West	3.0
2048999	546097	02/13/2017 8:00 am	02/15/2017 7:30 am	Café	2.8
2049000	546098	02/13/2017 8:00 am	02/15/2017 7:30 am	Kitchen	3.1
2049001	546099	02/13/2017 8:00 am	02/15/2017 7:30 am	Blank	< 0.4
2049002	546100	02/13/2017 8:00 am	02/15/2017 7:30 am	Blank	< 0.4
2049003	546101	02/13/2017 8:00 am	02/15/2017 7:30 am	Blank	< 0.4

Comment: A copy of this report was emailed to bawalker@aps.k12.co.us.

Distributed by: National Safety Products

Date Received: 02/22/2017 Date Logged: 02/22/2017 Date Analyzed: 02/22/2017 Date Reported: 02/22/2017

Report Reviewed By:

Report Approved By:

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.