

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 1017, 1159
NRSB Device Code 10302,10320

Laboratory Report for:

Property Tested:

Aurora Public Schools c-o Environmental
1369 Airport Boulevard
Aurora CO 80011

Lyn Knoll Elementary
12445 East 2nd Avenue
Aurora CO 80011

Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
2048875	546124	02/14/2017 7:30 am	02/16/2017 7:30 am	Café North	1.2
2048876	546125	02/14/2017 7:30 am	02/16/2017 7:30 am	Café South	1.0
2048877	546126	02/14/2017 7:30 am	02/16/2017 7:30 am	Kitchen	0.8
2048878	546127	02/14/2017 7:30 am	02/16/2017 7:30 am	Kitchen Office	0.7
2048879	546128	02/14/2017 7:30 am	02/16/2017 7:30 am	Media North	5.1
2048880	546129	02/14/2017 7:30 am	02/16/2017 7:30 am	Computer Lab South	6.0
2048881	546130	02/14/2017 7:30 am	02/16/2017 7:30 am	B5	3.6
2048882	546131	02/14/2017 7:30 am	02/16/2017 7:30 am	B5 Duplicate	4.1
2048883	546132	02/14/2017 7:30 am	02/16/2017 7:30 am	B4	2.6
2048884	546133	02/14/2017 7:30 am	02/16/2017 7:30 am	B3	2.9

Comment: A copy of this report was emailed to bawalker@aps.k12.co.us.

Distributed by: National Safety Products

Date Received: 02/21/2017 Date Logged: 02/21/2017 Date Analyzed: 02/21/2017 Date Reported: 02/21/2017

Report Reviewed By:

Report Approved By:

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 1017, 1159
NRSB Device Code 10302,10320

Laboratory Report for:

Property Tested:

Aurora Public Schools c-o Environmental
1369 Airport Boulevard
Aurora CO 80011

Lyn Knoll Elementary
12445 East 2nd Avenue
Aurora CO 80011

Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
2048885	546134	02/14/2017 7:30 am	02/16/2017 7:30 am	B Wing Resource Room	3.1
2048886	546135	02/14/2017 7:30 am	02/16/2017 7:30 am	M1	0.9
2048887	546136	02/14/2017 7:30 am	02/16/2017 7:30 am	M2	1.1
2048888	546137	02/14/2017 7:30 am	02/16/2017 7:30 am	M3	0.9
2048889	546138	02/14/2017 7:30 am	02/16/2017 7:30 am	M4	1.1
2048890	546139	02/14/2017 7:30 am	02/16/2017 7:30 am	M5	0.6
2048891	546240	02/14/2017 7:30 am	02/16/2017 7:30 am	M6	0.6
2048892	546243	02/14/2017 7:30 am	02/16/2017 7:30 am	M6 Duplicate	0.9
2048893	546248	02/14/2017 7:30 am	02/16/2017 7:30 am	Field Blank	< 0.4
2048894	546250	02/14/2017 7:30 am	02/16/2017 7:30 am	Field Blank	< 0.4

Comment: A copy of this report was emailed to bawalker@aps.k12.co.us.

Distributed by: National Safety Products

Date Received: 02/21/2017 Date Logged: 02/21/2017 Date Analyzed: 02/21/2017 Date Reported: 02/21/2017

Report Reviewed By:

Report Approved By:

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 1017, 1159
NRSB Device Code 10302,10320

Laboratory Report for:

Property Tested:

Aurora Public Schools c-o Environmental
1369 Airport Boulevard
Aurora CO 80011


Lyn Knoll Elementary
12445 East 2nd Avenue
Aurora CO 80011


Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
2048895	546264	02/14/2017 7:30 am	02/16/2017 7:30 am	Speech	0.9
2048896	546265	02/14/2017 7:30 am	02/16/2017 7:30 am	PE Office	1.1

Comment: A copy of this report was emailed to bawalker@aps.k12.co.us.

Distributed by: National Safety Products

Date Received: 02/21/2017 Date Logged: 02/21/2017 Date Analyzed: 02/21/2017 Date Reported: 02/21/2017

Report Reviewed By: 

Report Approved By: 

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.