



SUMMARY OF RADON INSPECTION

Environmental

Site Address:

West Middle School
 10100 E 13th Ave
 Aurora, CO 80010

Detector#	Location Room	Placement	Retrieval	Result pCi/L
4138490	Main office hall	10/29/07 12:00	11/01/07 11:00	5.1 (Elevated)
4138491	A108	10/29/07 12:00	11/01/07 11:00	4.0
4138489	A107	10/29/07 12:00	11/01/07 11:00	5.5 (Elevated)
4138492	A106	10/29/07 12:00	11/01/07 11:00	3.5
4138487	A105	10/29/07 12:00	11/01/07 11:00	3.5
4138483	A104	10/29/07 12:00	11/01/07 11:00	3.4
4138480	A103	10/29/07 12:00	11/01/07 11:00	5.0 (Elevated)
4138481	A101 main	10/29/07 12:00	11/01/07 11:00	3.7
4138479	Cafe NW	10/29/07 12:00	11/01/07 11:00	4.2 (Elevated)
4138478	Cafe SE	10/29/07 12:00	11/01/07 11:00	4.1 (Elevated)
4138493	Lounge	10/29/07 12:00	11/01/07 11:00	4.1 (Elevated)
4138494	Litchen	10/29/07 12:00	11/01/07 11:00	6.4 (Elevated)
4138495	Cust off kitchen	10/29/07 12:00	11/01/07 11:00	4.2 (Elevated)
4138498	A102	10/29/07 12:00	11/01/07 11:00	4.7 (Elevated)
4138497	A101 office	10/29/07 12:00	11/01/07 11:00	3.4
4138496	A10 office	10/29/07 12:00	11/01/07 11:00	3.5 duplicate
4138680	Blank	10/29/07 12:00	11/01/07 11:00	<0.3
4138466	C116	10/29/07 12:00	11/01/07 11:00	3.5
4138449	114	10/29/07 12:00	11/01/07 11:00	2.9
4138477	C112	10/29/07 12:00	11/01/07 11:00	3.7
4138471	C110	10/29/07 12:00	11/01/07 11:00	2.9
4138470	C108	10/29/07 12:00	11/01/07 11:00	3.8
4138469	C106	10/29/07 12:00	11/01/07 11:00	3.5
4138468	C104	10/29/07 12:00	11/01/07 11:00	3.3
4138467	C102	10/29/07 12:00	11/01/07 11:00	4.6 (Elevated)
4138465	C105	10/29/07 12:00	11/01/07 11:00	3.3
4138442	C103	10/29/07 12:00	11/01/07 11:00	2.1
4138405	C101	10/29/07 12:00	11/01/07 11:00	2.3
4013472	C100	10/29/07 12:00	11/01/07 11:00	6.4 (Elevated)
4138482	A118	10/29/07 12:00	11/01/07 11:00	4.3 (Elevated)
4138476	A115	10/29/07 12:00	11/01/07 11:00	3.9
4138485	A117	10/29/07 12:00	11/01/07 11:00	4.8 (Elevated)
4138484	A116	10/29/07 12:00	11/01/07 11:00	1.9
4138486	A114	10/29/07 12:00	11/01/07 11:00	5.1 (elevated)
4138474	A113	10/29/07 12:00	11/01/07 11:00	5.5 (elevated)

4138475	A112	10/29/07 12:00	11/01/07 11:00	5.2 (Elevated)
4138473	A109 wkrm	10/29/07 12:00	11/01/07 11:00	10.2 (Elevated)
4138488	A109 wkrm	10/29/07 12:00	11/01/07 11:00	9.6 (Duplicate)
4138411	C126	10/29/07 12:00	11/01/07 11:00	1.0
4138401	C124	10/29/07 12:00	11/01/07 11:00	0.7
4138410	C125	10/29/07 12:00	11/01/07 11:00	2.0
4138456	C123	10/29/07 12:00	11/01/07 11:00	2.9
4138409	C121	10/29/07 12:00	11/01/07 11:00	5.8 (Elevated)
4138462	C122	10/29/07 12:00	11/01/07 11:00	1.3
4138784	C120	10/29/07 12:00	11/01/07 11:00	1.7
4138402	C135	10/29/07 12:00	11/01/07 11:00	2.6
4138404	Boys locker room	10/29/07 12:00	11/01/07 11:00	3.1
4138782	Girls locker room	10/29/07 12:00	11/01/07 11:00	2.6
4138407	Art C135	10/29/07 12:00	11/01/07 11:00	2.3
4138403	Conf BR04	10/29/07 12:00	11/01/07 11:00	2.6
4138441	Art Office	10/29/07 12:00	11/01/07 11:00	2.3
4138446	Media NE	10/29/07 12:00	11/01/07 11:00	0.9
4138459	Media SW	10/29/07 12:00	11/01/07 11:00	0.8
4138783	Media office	10/29/07 12:00	11/01/07 11:00	1.3
4138786	Media wkrm	10/29/07 12:00	11/01/07 11:00	0.9
4138408	Computer Lab	10/29/07 12:00	11/01/07 11:00	0.9
4138450	103	10/29/07 12:00	11/01/07 11:00	1.6
4138464	102	10/29/07 12:00	11/01/07 11:00	3.0
4138436	102	10/29/07 12:00	11/01/07 11:00	3.0 duplicate
4138453	C144	10/29/07 12:00	11/01/07 11:00	0.7
4138448	Voc Music office	10/29/07 12:00	11/01/07 11:00	1.1
4138438	Voc music T102	10/29/07 12:00	11/01/07 11:00	1.1
4138451	C142	10/29/07 12:00	11/01/07 11:00	1.2
4138454	C140	10/29/07 12:00	11/01/07 11:00	1.6
4138452	Aud Stage	10/29/07 12:00	11/01/07 11:00	0.9
4138443	Aud Front	10/29/07 12:00	11/01/07 11:00	1.0
4138444	Fitness	10/29/07 12:00	11/01/07 11:00	1.3
4138461	Gym NE	10/29/07 12:00	11/01/07 11:00	3.1
4138460	Gym SW	10/29/07 12:00	11/01/07 11:00	2.8
4138457	Cust by gym	10/29/07 12:00	11/01/07 11:00	2.4
4138458	C134	10/29/07 12:00	11/01/07 11:00	3.0
4138437	CR C133	10/29/07 12:00	11/01/07 11:00	2.1
4138439	CR133 office	10/29/07 12:00	11/01/07 11:00	1.8
4138440	C132	10/29/07 12:00	11/01/07 11:00	2.0
4138779	Wkrm E102	10/29/07 12:00	11/01/07 11:00	3.3
4138406	C130	10/29/07 12:00	11/01/07 11:00	1.7
4138445	Wkrm E101	10/29/07 12:00	11/01/07 11:00	2.5

4138412	C131	10/29/07 12:00	11/01/07 11:00	3.3
4138455	C128	10/29/07 12:00	11/01/07 11:00	1.0
4138447	C128 duplicate	10/29/07 12:00	11/01/07 11:00	1.1 duplicate

RECOMMENDATIONS

Long term testing is recommended in all elevated rooms. All other rooms indicated radon levels below the EPA action guideline of 4.0 pCi/l. Please call us should you have any questions.

Sincerely,

Tammy Linton